




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE10293																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9833444560																			
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																
Ticket Type :	New Installation	Date & Time :	16-12-2023 11:44:15																	
Vendor Details :																				
Company Name/Client Name :	Comfort Inn Emerald Dapoli	Customer's Mobile :	9833444560	Name :	Abhay Mutreja															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Access																			
Complain :	ESSL access lock installation																			
Technician Comment :	room number 305 essl access lock install with configuration done one card and 3 key hondover to Dilip sir																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	room number 305 essl access lock install with configuration done one card and 3 key hondover to Dilip sir																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>16-12-2023 07:39:29</td><td>Ravi Rajbhar</td><td>Completed</td><td>room number 305 essl access lock install with configuration done one card and 3 key hondover to Dilip sir</td><td></td></tr><tr><td>16-12-2023 11:44:26</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	16-12-2023 07:39:29	Ravi Rajbhar	Completed	room number 305 essl access lock install with configuration done one card and 3 key hondover to Dilip sir		16-12-2023 11:44:26	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																
16-12-2023 07:39:29	Ravi Rajbhar	Completed	room number 305 essl access lock install with configuration done one card and 3 key hondover to Dilip sir																	
16-12-2023 11:44:26	Ravi Rajbhar	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>16-12-2023 11:45:51</td><td>Ravi Rajbhar</td><td>ppm done of cctv camera , fire ,access, PA system 1- cctv camera all ok working done check our side one camera trecece on off issue resolved 2 - fire panal all zone normal with mcp check all floor all ok working 3- PA system check one amplifier ok working resturanrt and recepatiin area second amplifier floor already remove 4- epbax complaints 108,209, both lift ,party area ,1sfloor and second floor 1st floor cable breck need to change cable 35-40 meter and service lift cable breck need to change cable lift room to lift in side 108 cable missing in room both side and need to cabling system to room 209 jack issue need to change 5- access already ok ok working and check our side</td></tr><tr><td>27-11-2023 01:36:55</td><td>Sonu Kumar</td><td>2tb hard disk install all working ok and 1camera off issue resolved working ok</td></tr></tbody></table>					Date Time	Technician Name	Remark	16-12-2023 11:45:51	Ravi Rajbhar	ppm done of cctv camera , fire ,access, PA system 1- cctv camera all ok working done check our side one camera trecece on off issue resolved 2 - fire panal all zone normal with mcp check all floor all ok working 3- PA system check one amplifier ok working resturanrt and recepatiin area second amplifier floor already remove 4- epbax complaints 108,209, both lift ,party area ,1sfloor and second floor 1st floor cable breck need to change cable 35-40 meter and service lift cable breck need to change cable lift room to lift in side 108 cable missing in room both side and need to cabling system to room 209 jack issue need to change 5- access already ok ok working and check our side	27-11-2023 01:36:55	Sonu Kumar	2tb hard disk install all working ok and 1camera off issue resolved working ok						
Date Time	Technician Name	Remark																		
16-12-2023 11:45:51	Ravi Rajbhar	ppm done of cctv camera , fire ,access, PA system 1- cctv camera all ok working done check our side one camera trecece on off issue resolved 2 - fire panal all zone normal with mcp check all floor all ok working 3- PA system check one amplifier ok working resturanrt and recepatiin area second amplifier floor already remove 4- epbax complaints 108,209, both lift ,party area ,1sfloor and second floor 1st floor cable breck need to change cable 35-40 meter and service lift cable breck need to change cable lift room to lift in side 108 cable missing in room both side and need to cabling system to room 209 jack issue need to change 5- access already ok ok working and check our side																		
27-11-2023 01:36:55	Sonu Kumar	2tb hard disk install all working ok and 1camera off issue resolved working ok																		

