



Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | **W :** www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE13121					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	9833444560				
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965	
Ticket Type :	AMC visiting	Date & Time :	28-10-2024 11:06:59		
Vendor Details :					
Company Name/Client Name :	Comfort Inn Emerald Dapoli	Customer's Mobile :	9833444560	Name :	Abhay Mutreja
Address :					
Mumbai , , , , Maharashtra					
AMC Details :					
Expiry Date :	01-01-1970 05:30:00		Type :		
Product Name :	Ppm				
Complain :	CCTV/EPABX/PA/Access/Fire PPM need to do				
Technician Comment :	Ppm done off cctv cmaera system, fire alarm system, access abhay sir cabin, intercom system PA system all ok working done Including complaint resolved intercom , 206, 302 102, 101 , and 111 ex fist floor need to change cable inform to dilip sir And cctv 3- 4 cmaera issue resolved and ok working done Used 3 video valune with dc pin				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	Ppm done off cctv cmaera system, fire alarm system, access abhay sir cabin, intercom system PA system all ok working done Including complaint resolved intercom , 206, 302 102, 101 , and 111 ex fist floor need to change cable inform to dilip sir And cctv 3- 4 cmaera issue resolved and ok working done Used 3 video valune with dc pin				

Status History :					
	Date Time	Technician Name	Status	Remark	Sign
	28-10-2024 06:40:16	Ravi Rajbhar	Completed	Ppm done off cctv cmaera system, fire alarm system, access abhay sir cabin, intercom system PA system all ok working done Including complaint resolved intercom , 206, 302 102, 101 , and 111 ex fist floor need to change cable inform to dilip sir And cctv 3- 4 cmaera issue resolved and ok working done Used 3 video valune with dc pin	
	28-10-2024 06:40:11	Ravi Rajbhar	Completed	Ppm done off cctv cmaera system, fire alarm system, access abhay sir cabin, intercom system PA system all ok working done Including complaint resolved intercom , 206, 302 102, 101 , and 111 ex fist floor need to change cable inform to dilip sir And cctv 3- 4 cmaera issue resolved and ok working done Used 3 video valune with dc pin	
	28-10-2024 11:07:14	Ravi Rajbhar	New		-
Previous Complain History :					
	Date Time	Technician Name	Remark		
	28-10-2024 11:05:54	Ravi Rajbhar	3- 4 cmaera issue resolved and ok working done used 3 videos valuen And biometric access divice allready ok working done		
	10-08-2024 04:24:25	Ravi Rajbhar			