


Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE2435					
Priority :	High				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	9833444560				
Technician Name :	Atique Salmani		Technician Mobile :	8080922984	
Ticket Type :	Complain	Date & Time :	16-12-2020 10:24:28		
Vendor Details :					
Company Name/Client Name :	Comfort Inn Emerald	Customer's Mobile :	9833444560	Name :	Abhay Mutreja
Address :					
Mumbai , , , , Maharashtra					
AMC Details :					
Expiry Date :	01-01-1970 05:30:00		Type :		
Product Name :	Ppm				
Complain :	ppm to be done				
Technician Comment :	Dapoli intercon cimplain Details 1.108 boath done working ok 2.308 boath done working ok. Changed rj11 femle conectors 3.309 done working ok bathroom cable Faulty need to chenged 4.208 done working ok bathroom instrument issue line ok 5.209 Boath done working ok 6.109 bathroom cable fauty need to changed 7.222 2nd floor Pantry done 8.444 lift also done working ok Dapoli CCTV Daitails dvr 1.only 3 cameras conected Data available from 8october 2020 to 16/12/2020 Hdd. 1tb normal Frame rate 15 Fps Bit rates 512 Quality medeum Dvr 2 cameras concted 16 Data available from 28 novembr 2020 to 16 /12/2020 Hdd 2tb normal Frame rate 15 Fps Bitrate 512 Quality medeum Dvr 3cameras concted 16 Data available from 28 november 2020 to 16/12/2020 Hdd2tb normal Frame 15 Bit 512 Quality medeum And also check fire alarm panel conction proper And also check mnual from frist floor and reste				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	Dapoli intercon cimplain Details 1.108 boath done working ok 2.308 boath done working ok. Changed rj11 femle conectors 3.309 done working ok bathroom cable Faulty need to chenged 4.208 done working ok bathroom instrument issue line ok 5.209 Boath done working ok 6.109 bathroom cable fauty need to changed 7.222 2nd floor Pantry done 8.444 lift also done working ok Dapoli CCTV Daitails dvr 1.only 3 cameras conected Data available from 8october 2020 to 16/12/2020 Hdd. 1tb normal Frame rate 15 Fps Bit rates 512 Quality medeum Dvr 2 cameras concted 16 Data available from 28 novembr 2020 to 16 /12/2020 Hdd 2tb normal Frame rate 15 Fps Bitrate 512 Quality medeum Dvr 3cameras concted 16 Data available from 28 november 2020 to 16/12/2020 Hdd2tb normal Frame 15 Bit 512 Quality medeum And also check fire alarm panel conction proper And also check mnual from frist floor and reste				

Status History :	Date Time	Technician Name	Status	Remark	Sign
	16-12-2020 08:58:14	Atique Salmani	Completed	Dapoli intercon cimplain Details 1.108 boath done working ok 2.308 boath done working ok. Changed rj11 femle conectors 3.309 done working ok bathroom cable Faulty need to chenged 4.208 done working ok bathroom instrument issue line ok 5.209 Boath done working ok 6.109 bathroom cable fauty need to changed 7.222 2nd floor Pantry done 8.444 lift also done working ok Dapoli CCTV Datails dvr 1.only 3 cameras conected Data available from 8october 2020 to 16/12/2020 Hdd. 1tb normal Frame rate 15 Fps Bit rates 512 Quality medeum Dvr 2 cameras concted 16 Data available from 28 novembr 2020 to 16 /12/2020 Hdd 2tb normal Frame rate 15 Fps Bitrate 512 Quality medeum Dvr 3cameras concted 16 Data available from 28 november 2020 to 16/12/2020 Hdd2tb normal Frame 15 Bit 512 Quality medeum And also check fire alarm panel conction proper And also check mnual from frist floor and reste	
	16-12-2020 10:24:50	Atique Salmani	New		-
	16-12-2020 10:24:28	Atique Salmani	New		-
Previous Complain History :	Date Time	Technician Name	Remark		
	30-05-2023 01:21:51	Ravi Rajbhar	ppm also done by atik only 1st floor room no. 102 smoke basse change and ok working done and faulty bess return to confirm to falguni mdm		
	21-02-2023 10:16:23	MayurYadav	All system check Ppm done Cctv working ok Fire working ok		