




# Vallabh Enterprises

**Regd. Office :** 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067  
**Support : | W :** www.vallabhenterprises.com  
**E :** vallabhsecure@yahoo.co.in

<b>Service Status Details : VE2729</b>																									
<b>Priority :</b>	Low																								
<b>Created By :</b>	Admin - Apurva Vajaria																								
<b>Complaint Mob. No. :</b>	9833444560																								
<b>Technician Name :</b>	Ravi Rajbhar		<b>Technician Mobile :</b>	8080922965																					
<b>Ticket Type :</b>	Complain	<b>Date &amp; Time :</b>	24-02-2021 09:55:29																						
<b>Vendor Details :</b>																									
Company Name/Client Name :	Comfort Inn Emerald	Customer's Mobile :	9833444560	Name :	Abhay Mutreja																				
<b>Address :</b>																									
Mumbai , , , , Maharashtra																									
<b>AMC Details :</b>																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
<b>Product Name :</b>	Fire																								
<b>Complain :</b>	fire alarm system giving false alarm PA system usb port issue																								
<b>Technician Comment :</b>	amplifier issue resolved and ok working done connect to phone fire system 1 th floor ( 105 heat detector with base change and 3 th floor 301 base change and 305 base change and ok working done and besment office em lock alament issue resolved and fire alarm system all zone Normal faulty base return with detector																								
<b>Complain Operator :</b>	Desktop - Apurva Vajaria																								
<b>Remark :</b>	amplifier issue resolved and ok working done connect to phone fire system 1 th floor ( 105 heat detector with base change and 3 th floor 301 base change and 305 base change and ok working done and besment office em lock alament issue resolved and fire alarm system all zone Normal faulty base return with detector																								
<b>Status History :</b>	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>25-02-2021 12:22:26</td><td>Ravi Rajbhar</td><td>Completed</td><td>amplifier issue resolved and ok working done connect to phone fire system 1 th floor ( 105 heat detector with base change and 3 th floor 301 base change and 305 base change and ok working done and besment office em lock alament issue resolved and fire alarm system all zone Normal faulty base return with detector</td><td></td></tr><tr><td>24-02-2021 09:55:44</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr><tr><td>24-02-2021 09:55:29</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	25-02-2021 12:22:26	Ravi Rajbhar	Completed	amplifier issue resolved and ok working done connect to phone fire system 1 th floor ( 105 heat detector with base change and 3 th floor 301 base change and 305 base change and ok working done and besment office em lock alament issue resolved and fire alarm system all zone Normal faulty base return with detector		24-02-2021 09:55:44	Ravi Rajbhar	New		-	24-02-2021 09:55:29	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																					
25-02-2021 12:22:26	Ravi Rajbhar	Completed	amplifier issue resolved and ok working done connect to phone fire system 1 th floor ( 105 heat detector with base change and 3 th floor 301 base change and 305 base change and ok working done and besment office em lock alament issue resolved and fire alarm system all zone Normal faulty base return with detector																						
24-02-2021 09:55:44	Ravi Rajbhar	New		-																					
24-02-2021 09:55:29	Ravi Rajbhar	New		-																					

Previous Complain History :	Date Time	Technician Name	Remark
	30-05-2023 01:21:51	Ravi Rajbhar	ppm also done by atik only 1st floor room no. 102 smoke basse change and ok working done and faulty bess return to confirm to falguni mdm
	21-02-2023 10:16:23	MayurYadav	All system check Ppm done Cctv working ok Fire working ok