



Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | **W :** www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE8451					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	9833444560				
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965	
Ticket Type :	AMC visiting	Date & Time :	30-05-2023 01:21:51		
Vendor Details :					
Company Name/Client Name :	Comfort Inn Emerald	Customer's Mobile :	9833444560	Name :	Abhay Mutreja
Address :					
Mumbai , , , , Maharashtra					
AMC Details :					
Expiry Date :	01-01-1970 05:30:00		Type :		
Product Name :	Ppm				
Complain :	CCTV/ EPABX/PA/Access/Fire PPM Need to do				
Technician Comment :	ppm also done by atik only 1st floor room no. 102 smoke basse change and ok working done and faulty bess return to confirm to falguni mdm				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	ppm also done by atik only 1st floor room no. 102 smoke basse change and ok working done and faulty bess return to confirm to falguni mdm				

Status History :	Date Time	Technician Name	Status	Remark	Sign
	13-06-2023 08:15:36	Ravi Rajbhar	Completed	ppm also done by atik only 1st floor room no. 102 smoke basse change and ok working done and faulty bess return to confirm to falguni mdm	
	13-06-2023 06:55:24	Ravi Rajbhar	New		-
	03-06-2023 11:40:13	Ravi Rajbhar	New		-
	30-05-2023 07:19:20	Ravi Rajbhar	Work Pending	Ppm done 1st floor and 3 floor passage camera issue resolved and south side bullet camera mode didn't changed so it's painding need to changed bullet camera And decoder hand over to faeez reception 108 intercom cable faulty Fire panel clean cahek all connections and in fire panel batter missing . Also pa system working ok. Check decter maully and chaek all floor mcp by fire it's properly working all zones normal	
	30-05-2023 01:21:57	Ravi Rajbhar	New		-
Previous Complain History :	Date Time	Technician Name	Remark		
	21-02-2023 10:16:23	MayurYadav	All system check Ppm done Cctv working ok Fire working ok		
	02-02-2023 06:14:23	MayurYadav			