




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE868																									
Priority :	High																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9833444560																								
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																					
Ticket Type :	Complain	Date & Time :	06-01-2020 07:20:54																						
Vendor Details :																									
Company Name/Client Name :	Comfort Inn Emerald	Customer's Mobile :	9833444560	Name :	Abhay Mutreja																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Fire																								
Complain :	smoke sensor giving false alaram																								
Technician Comment :	reception s. d. open and cleaned by w. D. 40 and restaurant h. d. is sence the flow of ac foggy air so that heat detector need to be shifted and one intercom issue 126 ext. issue resolved anddd cctv cameras clean which is reachable and check cctv system all ok and also check mcp and floor S.D. and H. D. all working ok																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	reception s. d. open and cleaned by w. D. 40 and restaurant h. d. is sence the flow of ac foggy air so that heat detector need to be shifted and one intercom issue 126 ext. issue resolved anddd cctv cameras clean which is reachable and check cctv system all ok and also check mcp and floor S.D. and H. D. all working ok																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>07-01-2020 05:21:19</td><td>Atique Salmani</td><td>Completed</td><td>reception s. d. open and cleaned by w. D. 40 and restaurant h. d. is sence the flow of ac foggy air so that heat detector need to be shifted and one intercom issue 126 ext. issue resolved anddd cctv cameras clean which is reachable and check cctv system all ok and also check mcp and floor S.D. and H. D. all working ok</td><td></td></tr><tr><td>06-01-2020 07:21:02</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr><tr><td>06-01-2020 07:20:55</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	07-01-2020 05:21:19	Atique Salmani	Completed	reception s. d. open and cleaned by w. D. 40 and restaurant h. d. is sence the flow of ac foggy air so that heat detector need to be shifted and one intercom issue 126 ext. issue resolved anddd cctv cameras clean which is reachable and check cctv system all ok and also check mcp and floor S.D. and H. D. all working ok		06-01-2020 07:21:02	Atique Salmani	New		-	06-01-2020 07:20:55	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																					
07-01-2020 05:21:19	Atique Salmani	Completed	reception s. d. open and cleaned by w. D. 40 and restaurant h. d. is sence the flow of ac foggy air so that heat detector need to be shifted and one intercom issue 126 ext. issue resolved anddd cctv cameras clean which is reachable and check cctv system all ok and also check mcp and floor S.D. and H. D. all working ok																						
06-01-2020 07:21:02	Atique Salmani	New		-																					
06-01-2020 07:20:55	Atique Salmani	New		-																					

Previous Complain History :			
	Date Time	Technician Name	Remark
	30-05-2023 01:21:51	Ravi Rajbhar	ppm also done by atik only 1st floor room no. 102 smoke basse change and ok working done and faulty bess return to confirm to falguni mdm
	21-02-2023 10:16:23	MayurYadav	All system check Ppm done Cctv working ok Fire working ok