


Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE11077					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	9833036026				
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965	
Ticket Type :	Complain	Date & Time :	09-03-2024 02:21:59		
Vendor Details :					
Company Name/Client Name :	Agam Bhai BKC	Customer's Mobile :	9833036026	Name :	Agam Bhai
Address :					
mumbai , , , 400067 , Maharashtra					
AMC Details :					
Expiry Date :	01-01-1970 05:30:00		Type :		
Product Name :	Access				
Complain :	access system need to check				
Technician Comment :	access door power supply change and old 4 amp supply remove and take to office and all door with lock ok working done				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	access door power supply change and old 4 amp supply remove and take to office and all door with lock ok working done				
Status History :	Date Time	Technician Name	Status	Remark	Sign
	13-03-2024 06:11:36	Ravi Rajbhar	Completed	access door power supply change and old 4 amp supply remove and take to office and all door with lock ok working done	
	13-03-2024 05:51:13	Ravi Rajbhar	New		-
	09-03-2024 04:13:18	Ravi Rajbhar	Work Pending	10 mpr ki supply thi uski jagah par 5 mpr ki supply installation Kiya hu.kaam pending kyu ki waha par 10 mpr ki supply insstt karni padegi. asses working ok	
	09-03-2024 02:23:07	Ravi Rajbhar	New		-

Previous Complain History :	Date Time		
	Technician Name		
	Remark		
	28-02-2022 04:07:59	Prashant Nikalje	6 hikvision access cantrol divice remove and take to office 05.03.2022 - 6 hikvision fingerprint access device repair and install 5 working ok 1 card issue in device essl software configuration pending 07.03.2022 - 6 hikvision essl etime track software install and configuration done