Vallabh Enterprises

 $\label{eq:Regd.office:401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067 \\ \text{Support:} \mid \mathbf{W}: \text{www.vallabhenterprises.com} \\ \mathbf{E}: \text{vallabhsecure@yahoo.co.in}$

Service Status Details	: VE717								
Priority:	High								
Created By:	Admin - Apurva Vajaria								
Complaint Mob. No. :	9825166631								
Technician Name :	Yash Doshi			Technician Mobile :		8080922986			
Ticket Type :	Complain Date & Time		Time:	25-11-2019 11:23:59					
Vendor Details :	-								
Company Name/Client Name :	Concentrix Services India Pvt Ltd - Alembic			9825166631		Name :		Amar Sir	
Address:									
gujrat , , , 390003 , Ma	aharashtra								
AMC Details :	-								
Expiry Date :	01-01-1970 05:30:00			Type:					
Product Name:	Fire								
Complain:	During yesterday's weekly testing of security systems we found that when smoke detector was activated manually CAS doors did not get free.								
Technician Comment:									
Complain Operator :	Desktop - Apurva Vajaria								
Remark:	complain solved by dhrumil as on 27.11.2019 and they have kept under observation								
Status History :	Date Time		Technician Name		Status		Remark	Sign	Ī
	27-11-2019 11:04:23		YashDoshi		Completed			-	
	25-11-2019 11:26:21		YashDoshi		New			-	
	25-11-2019 11:24:00		YashDoshi		New			<u> </u>	
Previous Complain	Date Time		Technician Name		Remark				
History:	03-12-2020 07:36:19								1
	29-11-2020 10:08:28				re-aligr	ment of em lock done			
									_