




# Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067  
Support : | W : www.vallabhenterprises.com  
E : vallabhsecure@yahoo.co.in

<b>Service Status Details : VE1523</b>																									
<b>Priority :</b>	High																								
<b>Created By :</b>	Admin - Apurva Vajaria																								
<b>Complaint Mob. No. :</b>	9370310273																								
<b>Technician Name :</b>	Anil Yadav		<b>Technician Mobile :</b>	8080922983																					
<b>Ticket Type :</b>	Complain	<b>Date &amp; Time :</b>	08-07-2020 04:09:04																						
<b>Vendor Details :</b>																									
<b>Company Name/Client Name :</b>	Bellavista Building	<b>Customer's Mobile :</b>	9370310273	<b>Name :</b>	Arun Jain																				
<b>Address :</b>																									
Mumbai , , , , Maharashtra																									
<b>AMC Details :</b>																									
<b>Expiry Date :</b>	01-01-1970 05:30:00		<b>Type :</b>																						
<b>Product Name :</b>	Intercom																								
<b>Complain :</b>	four five flat intercom issue																								
<b>Technician Comment :</b>	1)1001, 1303, 1902 cable not connected home junction to Instument this complaint solve. 2). 1503 and 1304 connection was dead so not working. l do this complaint solve also.																								
<b>Complain Operator :</b>	Desktop - Apurva Vajaria																								
<b>Remark :</b>	1)1001, 1303, 1902 cable not connected home junction to Instument this complaint solve. 2). 1503 and 1304 connection was dead so not working. l do this complaint solve also.																								
<b>Status History :</b>	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>09-07-2020 01:50:07</td><td>AnilYadav</td><td>Completed</td><td>1)1001, 1303, 1902 cable not connected home junction to Instument this complaint solve. 2). 1503 and 1304 connection was dead so not working. l do this complaint solve also.</td><td></td></tr><tr><td>08-07-2020 05:48:34</td><td>AnilYadav</td><td>New</td><td></td><td>-</td></tr><tr><td>08-07-2020 04:09:05</td><td>AnilYadav</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	09-07-2020 01:50:07	AnilYadav	Completed	1)1001, 1303, 1902 cable not connected home junction to Instument this complaint solve. 2). 1503 and 1304 connection was dead so not working. l do this complaint solve also.		08-07-2020 05:48:34	AnilYadav	New		-	08-07-2020 04:09:05	AnilYadav	New		-
Date Time	Technician Name	Status	Remark	Sign																					
09-07-2020 01:50:07	AnilYadav	Completed	1)1001, 1303, 1902 cable not connected home junction to Instument this complaint solve. 2). 1503 and 1304 connection was dead so not working. l do this complaint solve also.																						
08-07-2020 05:48:34	AnilYadav	New		-																					
08-07-2020 04:09:05	AnilYadav	New		-																					
<b>Previous Complain History :</b>	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>10-08-2020 10:14:09</td><td>AnilYadav</td><td>ppm complite and Report handover to Jinal madam</td></tr><tr><td>01-07-2020 01:41:24</td><td>YogeshDesai</td><td>lift camera is ok only PowerPoint issues ppm work of cctv completed programming of intercom of 52 lines done vdp multiapartment chked</td></tr></tbody></table>					Date Time	Technician Name	Remark	10-08-2020 10:14:09	AnilYadav	ppm complite and Report handover to Jinal madam	01-07-2020 01:41:24	YogeshDesai	lift camera is ok only PowerPoint issues ppm work of cctv completed programming of intercom of 52 lines done vdp multiapartment chked											
Date Time	Technician Name	Remark																							
10-08-2020 10:14:09	AnilYadav	ppm complite and Report handover to Jinal madam																							
01-07-2020 01:41:24	YogeshDesai	lift camera is ok only PowerPoint issues ppm work of cctv completed programming of intercom of 52 lines done vdp multiapartment chked																							