

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE13737																																								
Priority :	Low																																							
Created By :	Admin - Apurva Vajaria																																							
Complaint Mob. No. :	9029045032																																							
Technician Name :	Rahul Mhapralkar		Technician Mobile :	9168762949																																				
Ticket Type :	AMC visiting	Date & Time :	04-01-2025 10:44:46																																					
Vendor Details :																																								
Company Name/Client Name :	Value Beverage	Customer's Mobile :	9029045032	Name :	Ashwini Madam																																			
Address :																																								
Mumbai , , , 400710 , Maharashtra																																								
AMC Details :																																								
Expiry Date :	01-01-1970 05:30:00		Type :																																					
Product Name :	CCTV																																							
Complain :	access PPM need to do																																							
Technician Comment :	All door working normally ppm done																																							
Complain Operator :	Desktop - Apurva Vajaria																																							
Remark :	All door working normally ppm done																																							
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>24-02-2025 01:29:08</td><td>Rahul Mhapralkar</td><td>Completed</td><td>All door working normally ppm done</td><td></td></tr><tr><td>24-02-2025 12:25:36</td><td>Rahul Mhapralkar</td><td>New</td><td></td><td>-</td></tr><tr><td>08-01-2025 03:57:18</td><td>Rahul Mhapralkar</td><td>Work Pending</td><td></td><td>-</td></tr><tr><td>07-01-2025 01:13:42</td><td>Rahul Mhapralkar</td><td>Completed</td><td>New adapter installed vdp now working normally</td><td></td></tr><tr><td>04-01-2025 05:32:19</td><td>Rahul Mhapralkar</td><td>Work Pending</td><td>pending to get access cards status of working or not pls reschedule morning visit demo n training given of soft ware login</td><td></td></tr><tr><td>04-01-2025 10:45:51</td><td>Rahul Mhapralkar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	24-02-2025 01:29:08	Rahul Mhapralkar	Completed	All door working normally ppm done		24-02-2025 12:25:36	Rahul Mhapralkar	New		-	08-01-2025 03:57:18	Rahul Mhapralkar	Work Pending		-	07-01-2025 01:13:42	Rahul Mhapralkar	Completed	New adapter installed vdp now working normally		04-01-2025 05:32:19	Rahul Mhapralkar	Work Pending	pending to get access cards status of working or not pls reschedule morning visit demo n training given of soft ware login		04-01-2025 10:45:51	Rahul Mhapralkar	New		-
Date Time	Technician Name	Status	Remark	Sign																																				
24-02-2025 01:29:08	Rahul Mhapralkar	Completed	All door working normally ppm done																																					
24-02-2025 12:25:36	Rahul Mhapralkar	New		-																																				
08-01-2025 03:57:18	Rahul Mhapralkar	Work Pending		-																																				
07-01-2025 01:13:42	Rahul Mhapralkar	Completed	New adapter installed vdp now working normally																																					
04-01-2025 05:32:19	Rahul Mhapralkar	Work Pending	pending to get access cards status of working or not pls reschedule morning visit demo n training given of soft ware login																																					
04-01-2025 10:45:51	Rahul Mhapralkar	New		-																																				

Previous Complain History :			
	Date Time	Technician Name	Remark
	08-03-2025 06:14:03	Ravi Rajbhar	Access control panal integration with fire alarm system incase fire then all door open
	24-02-2025 10:25:32	Rahul Mhapralkar	Rm door back side reader faulty change reader working normally