

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE15101																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9029045032																								
Technician Name :	Rahul Mhapralkar		Technician Mobile :	9168762949																					
Ticket Type :	Complain	Date & Time :	25-06-2025 11:40:27																						
Vendor Details :																									
Company Name/Client Name :	Value Beverage	Customer's Mobile :	9029045032	Name :	Ashwini Madam																				
Address :																									
Mumbai , , , 400710 , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Access																								
Complain :	1)Due to a smoke alarm, all access doors got auto-deactivated. the ZK BioCV app is also not connecting.																								
Technician Comment :	Software issue resolved, ppm done																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	Software issue resolved, ppm done																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>26-06-2025 05:31:35</td><td>Rahul Mhapralkar</td><td>Completed</td><td>Software issue resolved, ppm done</td><td></td></tr><tr><td>26-06-2025 10:34:39</td><td>Rahul Mhapralkar</td><td>New</td><td></td><td>-</td></tr><tr><td>25-06-2025 11:40:35</td><td>Rahul Mhapralkar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	26-06-2025 05:31:35	Rahul Mhapralkar	Completed	Software issue resolved, ppm done		26-06-2025 10:34:39	Rahul Mhapralkar	New		-	25-06-2025 11:40:35	Rahul Mhapralkar	New		-
Date Time	Technician Name	Status	Remark	Sign																					
26-06-2025 05:31:35	Rahul Mhapralkar	Completed	Software issue resolved, ppm done																						
26-06-2025 10:34:39	Rahul Mhapralkar	New		-																					
25-06-2025 11:40:35	Rahul Mhapralkar	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>08-03-2025 06:14:03</td><td>Ravi Rajbhar</td><td>Access control panal integration with fire alarm system incase fire then all door open</td></tr><tr><td>24-02-2025 10:25:32</td><td>Rahul Mhapralkar</td><td>Rm door back side reader faulty change reader working normally</td></tr></tbody></table>					Date Time	Technician Name	Remark	08-03-2025 06:14:03	Ravi Rajbhar	Access control panal integration with fire alarm system incase fire then all door open	24-02-2025 10:25:32	Rahul Mhapralkar	Rm door back side reader faulty change reader working normally											
Date Time	Technician Name	Remark																							
08-03-2025 06:14:03	Ravi Rajbhar	Access control panal integration with fire alarm system incase fire then all door open																							
24-02-2025 10:25:32	Rahul Mhapralkar	Rm door back side reader faulty change reader working normally																							