Vallabh Enterprises

Regd. Office : 401, shanti kutir, shivaji road, near thakur international school, kandivali(west) mumbai - 400067 Support : | W : www.vallabhenterprises.com E : vallabhsecure@yahoo.co.in

Service Status Details : VE1409 **Priority** : High **Created By :** Admin - Apurva Vajaria **Complaint Mob.** 9980471704 **No. : Technician Name** Ravi Rajbhar **Technician Mobile** 8080922965 Complain 04-05-2020 09:04:50 **Ticket Type :** Date & Time : Vendor Details : Concentrix Customer's Mobile 9980471704 Dinesh Company Name : Name/Client Name Services India Pvt. Menon Ltd-- Ecospace4a Address : bangalore,,,560029, Maharashtra **AMC Details :** 01-01-1970 05:30:00 Expiry Date : Type : **Product Name :** Access **Complain**: Three access door not working 5 access door issue resolve only power? supply faulty it is not working and access control Technician **Comment** : panal supply ues on 5 access door working ok Complain Desktop - Apurva Vajaria **Operator** : **Remark** : 5 access door issue resolve only power? supply faulty it is not working and access control panal supply ues on 5 access door working ok **Status History : Date Time Technician Name** Status Remark Sign rom 10-05-2020 08:07:42 Ravi Rajbhar Completed 5 access door issue resolve only power? supply faulty it is not working and access control panal supply ues on 5 access door working ok 04-05-2020 09:05:03 Ravi Rajbhar New 04-05-2020 09:04:51 Ravi Rajbhar New Previous **Technician Name Date Time** Remark **Complain History** 08-11-2020 01:10:24 checked the server controller the cable was disconnected. Now both the door working fine 27-10-2020 10:12:46 YashDoshi Issue has been resolved as it was because of internal issue with CAS and the same was resolved by CAS team.