




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE1420																									
Priority :	High																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9980471704																								
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																					
Ticket Type :	Complain	Date & Time :	19-05-2020 01:15:53																						
Vendor Details :																									
Company Name/Client Name :	Concentrix Services India Pvt. Ltd-- Ecospace4a	Customer's Mobile :	9980471704	Name :	Dinesh Menon																				
Address :																									
bangalore , , , 560029 , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Access																								
Complain :	9th floor cas door issue (entry exit)																								
Technician Comment :	9th floor cafetaira area panal pawer supply faulty it is not working and new power supply chenge and ok working done																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	9th floor cafetaira area panal pawer supply faulty it is not working and new power supply chenge and ok working done																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>19-05-2020 04:25:33</td><td>Ravi Rajbhar</td><td>Completed</td><td>9th floor cafetaira area panal pawer supply faulty it is not working and new power supply chenge and ok working done</td><td></td></tr><tr><td>19-05-2020 01:16:05</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr><tr><td>19-05-2020 01:15:54</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	19-05-2020 04:25:33	Ravi Rajbhar	Completed	9th floor cafetaira area panal pawer supply faulty it is not working and new power supply chenge and ok working done		19-05-2020 01:16:05	Ravi Rajbhar	New		-	19-05-2020 01:15:54	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																					
19-05-2020 04:25:33	Ravi Rajbhar	Completed	9th floor cafetaira area panal pawer supply faulty it is not working and new power supply chenge and ok working done																						
19-05-2020 01:16:05	Ravi Rajbhar	New		-																					
19-05-2020 01:15:54	Ravi Rajbhar	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>08-11-2020 01:10:24</td><td></td><td>checked the server controller the cable was disconnected. Now both the door working fine</td></tr><tr><td>27-10-2020 10:12:46</td><td>YashDoshi</td><td>Issue has been resolved as it was because of internal issue with CAS and the same was resolved by CAS team.</td></tr></tbody></table>					Date Time	Technician Name	Remark	08-11-2020 01:10:24		checked the server controller the cable was disconnected. Now both the door working fine	27-10-2020 10:12:46	YashDoshi	Issue has been resolved as it was because of internal issue with CAS and the same was resolved by CAS team.											
Date Time	Technician Name	Remark																							
08-11-2020 01:10:24		checked the server controller the cable was disconnected. Now both the door working fine																							
27-10-2020 10:12:46	YashDoshi	Issue has been resolved as it was because of internal issue with CAS and the same was resolved by CAS team.																							