

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE10765																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	8796230983																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	Complain	Date & Time :	06-02-2024 10:15:48																	
Vendor Details :																				
Company Name/Client Name :	Secure Debt Management Consultants Llp	Customer's Mobile :	8796230983	Name :	Gaurav Kulkarni															
Address :																				
Mumbai , , , 400031 , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Fire																			
Complain :	fire survey need to do																			
Technician Comment :	Fire servey done total 5 fire pannel 1 Agni and ,4 ravel .																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Fire servey done total 5 fire pannel 1 Agni and ,4 ravel .																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>06-02-2024 01:47:40</td><td>Atique Salmani</td><td>Completed</td><td>Fire servey done total 5 fire pannel 1 Agni and ,4 ravel .</td><td></td></tr><tr><td>06-02-2024 10:15:55</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	06-02-2024 01:47:40	Atique Salmani	Completed	Fire servey done total 5 fire pannel 1 Agni and ,4 ravel .		06-02-2024 10:15:55	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
06-02-2024 01:47:40	Atique Salmani	Completed	Fire servey done total 5 fire pannel 1 Agni and ,4 ravel .																	
06-02-2024 10:15:55	Atique Salmani	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>31-01-2024 02:23:07</td><td>Atique Salmani</td><td>Wld ppm done checked sensor by water dropping and it's also hooting working ok pannel healthy. - Wrongly updated in other ticket (VE10695)</td></tr><tr><td>04-09-2023 11:36:54</td><td>Atique Salmani</td><td>Water leak detector pannel check Zone chek by manually And all connections in pannel chek working ok Pannel working on health condition.</td></tr></tbody></table>					Date Time	Technician Name	Remark	31-01-2024 02:23:07	Atique Salmani	Wld ppm done checked sensor by water dropping and it's also hooting working ok pannel healthy. - Wrongly updated in other ticket (VE10695)	04-09-2023 11:36:54	Atique Salmani	Water leak detector pannel check Zone chek by manually And all connections in pannel chek working ok Pannel working on health condition.						
Date Time	Technician Name	Remark																		
31-01-2024 02:23:07	Atique Salmani	Wld ppm done checked sensor by water dropping and it's also hooting working ok pannel healthy. - Wrongly updated in other ticket (VE10695)																		
04-09-2023 11:36:54	Atique Salmani	Water leak detector pannel check Zone chek by manually And all connections in pannel chek working ok Pannel working on health condition.																		