

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE10947																														
Priority :	Low																													
Created By :	Admin - Apurva Vajaria																													
Complaint Mob. No. :	8796230983																													
Technician Name :	Pravin Jagade		Technician Mobile :	7262044153																										
Ticket Type :	Complain	Date & Time :	23-02-2024 02:40:15																											
Vendor Details :																														
Company Name/Client Name :	Secure Debt Management Consultants Llp	Customer's Mobile :	8796230983	Name :	Gaurav Kulkarni																									
Address :																														
Mumbai , , , 400031 , Maharashtra																														
AMC Details :																														
Expiry Date :	01-01-1970 05:30:00		Type :																											
Product Name :	Fire																													
Complain :	1)Cabling for access and FAS connectivity 30 mtrs cable 2)12V 7AH Battery - 2 nos need to change																													
Technician Comment :	Office nmbr 129 2 nos fire pannel battery changed and removed battery fail fault pannel working in healthy condition and today 126 office nmbr today it's showing battery low so also need to changed this battery's and cabling work painding.																													
Complain Operator :	Desktop - Apurva Vajaria																													
Remark :	Office nmbr 129 2 nos fire pannel battery changed and removed battery fail fault pannel working in healthy condition and today 126 office nmbr today it's showing battery low so also need to changed this battery's and cabling work painding. 02.04.2024 - On mail confirmation received all working fine.																													
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>28-02-2024 11:18:54</td><td>PravinJagade</td><td>New</td><td></td><td>-</td></tr><tr><td>26-02-2024 10:10:35</td><td>PravinJagade</td><td>Work Pending</td><td></td><td>-</td></tr><tr><td>23-02-2024 06:31:13</td><td>PravinJagade</td><td>Completed</td><td>Office nmbr 129 2 nos fire pannel battery changed and removed battery fail fault pannel working in healthy condition and today 126 office nmbr today it's showing battery low so also need to changed this battery's and cabling work painding.</td><td></td></tr><tr><td>23-02-2024 02:40:22</td><td>PravinJagade</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	28-02-2024 11:18:54	PravinJagade	New		-	26-02-2024 10:10:35	PravinJagade	Work Pending		-	23-02-2024 06:31:13	PravinJagade	Completed	Office nmbr 129 2 nos fire pannel battery changed and removed battery fail fault pannel working in healthy condition and today 126 office nmbr today it's showing battery low so also need to changed this battery's and cabling work painding.		23-02-2024 02:40:22	PravinJagade	New		-
Date Time	Technician Name	Status	Remark	Sign																										
28-02-2024 11:18:54	PravinJagade	New		-																										
26-02-2024 10:10:35	PravinJagade	Work Pending		-																										
23-02-2024 06:31:13	PravinJagade	Completed	Office nmbr 129 2 nos fire pannel battery changed and removed battery fail fault pannel working in healthy condition and today 126 office nmbr today it's showing battery low so also need to changed this battery's and cabling work painding.																											
23-02-2024 02:40:22	PravinJagade	New		-																										

Previous Complain History :			
	Date Time	Technician Name	Remark
	06-02-2024 10:15:48	Atique Salmani	Fire servey done total 5 fire pannel 1 Agni and ,4 ravel .
	31-01-2024 02:23:07	Atique Salmani	Wld ppm done checked sensor by water dropping and it's also hootring working ok pannel healthy. - Wrongly updated in other ticket (VE10695)