


Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE11528					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	8796230983				
Technician Name :	Atique Salmani		Technician Mobile :	8080922984	
Ticket Type :	AMC visiting	Date & Time :	30-04-2024 10:56:47		
Vendor Details :					
Company Name/Client Name :	Secure Debt Management Consultants Llp	Customer's Mobile :	8796230983	Name :	Gaurav Kulkarni
Address :					
Mumbai , , , 400031 , Maharashtra					
AMC Details :					
Expiry Date :	01-01-1970 05:30:00		Type :		
Product Name :	Ppm				
Complain :	WLD PPM need to do				
Technician Comment :	Water leak detector pannel chek working healthy condition and also check sensor by water dripping all working ok with hooter.				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	Water leak detector pannel chek working healthy condition and also check sensor by water dripping all working ok with hooter.				
Status History :	Date Time	Technician Name	Status	Remark	Sign
	30-04-2024 04:53:40	Atique Salmani	Completed	Water leak detector pannel chek working healthy condition and also check sensor by water dripping all working ok with hooter.	
	30-04-2024 11:05:04	Atique Salmani	New		-
Previous Complain History :	Date Time	Technician Name	Remark		
	23-02-2024 02:40:15	PravinJagade	Office nmbr 129 2 nos fire pannel battery changed and removed battery fail fault pannel working in healthy condition and today 126 office nmbr today it's showing battery low so also need to changed this battery's and cabling work painding. 02.04.2024 - On mail confirmation received all working fine.		
	06-02-2024 10:15:48	Atique Salmani	Fire servey done total 5 fire pannel 1 Agni and ,4 ravel .		