




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE12941																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	8796230983																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	AMC visiting	Date & Time :	09-10-2024 11:34:30																	
Vendor Details :																				
Company Name/Client Name :	Secure Debt Management Consultants Llp	Customer's Mobile :	8796230983	Name :	Gaurav Kulkarni															
Address :																				
Mumbai , , , 400031 , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Ppm																			
Complain :	WLD PPM need to do																			
Technician Comment :	Wld pannel chek by water dropping it's also hootering propr And zone one healthy on water leakage detector pannel . Working ok.																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Wld pannel chek by water dropping it's also hootering propr And zone one healthy on water leakage detector pannel . Working ok.																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>09-10-2024 04:02:52</td><td>Atique Salmani</td><td>Completed</td><td>Wld pannel chek by water dropping it's also hootering propr And zone one healthy on water leakage detector pannel . Working ok.</td><td></td></tr><tr><td>09-10-2024 11:34:37</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	09-10-2024 04:02:52	Atique Salmani	Completed	Wld pannel chek by water dropping it's also hootering propr And zone one healthy on water leakage detector pannel . Working ok.		09-10-2024 11:34:37	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
09-10-2024 04:02:52	Atique Salmani	Completed	Wld pannel chek by water dropping it's also hootering propr And zone one healthy on water leakage detector pannel . Working ok.																	
09-10-2024 11:34:37	Atique Salmani	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>30-04-2024 10:56:47</td><td>Atique Salmani</td><td>Water leak detector pannel chek working healthy condition and also check sensor by water dripping all working ok with hooter.</td></tr><tr><td>23-02-2024 02:40:15</td><td>PravinJagade</td><td>Office nmbr 129 2 nos fire pannel battery changed and removed battery fail fault pannel working in healthy condition and today 126 office nmbr today it's showing battery low so also need to changed this battery's and cabling work painding. 02.04.2024 - On mail confirmation received all working fine.</td></tr></tbody></table>					Date Time	Technician Name	Remark	30-04-2024 10:56:47	Atique Salmani	Water leak detector pannel chek working healthy condition and also check sensor by water dripping all working ok with hooter.	23-02-2024 02:40:15	PravinJagade	Office nmbr 129 2 nos fire pannel battery changed and removed battery fail fault pannel working in healthy condition and today 126 office nmbr today it's showing battery low so also need to changed this battery's and cabling work painding. 02.04.2024 - On mail confirmation received all working fine.						
Date Time	Technician Name	Remark																		
30-04-2024 10:56:47	Atique Salmani	Water leak detector pannel chek working healthy condition and also check sensor by water dripping all working ok with hooter.																		
23-02-2024 02:40:15	PravinJagade	Office nmbr 129 2 nos fire pannel battery changed and removed battery fail fault pannel working in healthy condition and today 126 office nmbr today it's showing battery low so also need to changed this battery's and cabling work painding. 02.04.2024 - On mail confirmation received all working fine.																		