

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE5218																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	8796230983																								
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																					
Ticket Type :	Complain	Date & Time :	15-04-2022 11:52:10																						
Vendor Details :																									
Company Name/Client Name :	Secure Debt Management Consultants Llp	Customer's Mobile :	8796230983	Name :	Gaurav Kulkarni																				
Address :																									
Mumbai , , , 400031 , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	wLD																								
Complain :	WLD survey																								
Technician Comment :	check wld system zone healthy it's working ok use SMPS for hooter bec pannel 12 volt output not giving so use saprate SMPS .																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	check wld system zone healthy it's working ok use SMPS for hooter bec pannel 12 volt output not giving so use saprate SMPS .																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>15-04-2022 04:40:14</td><td>Atique Salmani</td><td>Completed</td><td>check wld system zone healthy it's working ok use SMPS for hooter bec pannel 12 volt output not giving so use saprate SMPS .</td><td></td></tr><tr><td>15-04-2022 11:52:22</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr><tr><td>15-04-2022 11:52:10</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	15-04-2022 04:40:14	Atique Salmani	Completed	check wld system zone healthy it's working ok use SMPS for hooter bec pannel 12 volt output not giving so use saprate SMPS .		15-04-2022 11:52:22	Atique Salmani	New		-	15-04-2022 11:52:10	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																					
15-04-2022 04:40:14	Atique Salmani	Completed	check wld system zone healthy it's working ok use SMPS for hooter bec pannel 12 volt output not giving so use saprate SMPS .																						
15-04-2022 11:52:22	Atique Salmani	New		-																					
15-04-2022 11:52:10	Atique Salmani	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>09-12-2020 10:46:16</td><td>Atique Salmani</td><td>2 zone WLD pannel installed with cable laying in Server and also tested ok zone one.</td></tr></tbody></table>					Date Time	Technician Name	Remark	09-12-2020 10:46:16	Atique Salmani	2 zone WLD pannel installed with cable laying in Server and also tested ok zone one.														
Date Time	Technician Name	Remark																							
09-12-2020 10:46:16	Atique Salmani	2 zone WLD pannel installed with cable laying in Server and also tested ok zone one.																							