




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
 Support : | W : www.vallabhenterprises.com
 E : vallabhsecure@yahoo.co.in

Service Status Details : VE6550																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	8796230983																								
Technician Name :	Atique Salmani	Technician Mobile :	8080922984																						
Ticket Type :	Complain	Date & Time :	11-10-2022 11:34:29																						
Vendor Details :																									
Company Name/Client Name :	Secure Debt Management Consultants Llp	Customer's Mobile :	8796230983	Name :	Gaurav Kulkarni																				
Address :																									
Mumbai , , , 400031 , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00	Type :																							
Product Name :	Ppm																								
Complain :	WLD																								
Technician Comment :	checked w.l.d. system by water dropping and also it's hootring working ok zo e healthy an all lamps test working ok.																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	checked w.l.d. system by water dropping and also it's hootring working ok zo e healthy an all lamps test working ok.																								
Status History :	<table border="1"> <thead> <tr> <th>Date Time</th> <th>Technician Name</th> <th>Status</th> <th>Remark</th> <th>Sign</th> </tr> </thead> <tbody> <tr> <td>11-10-2022 01:01:48</td> <td>Atique Salmani</td> <td>Completed</td> <td>checked w.l.d. system by water dropping and also it's hootring working ok zo e healthy an all lamps test working ok.</td> <td></td> </tr> <tr> <td>11-10-2022 11:35:47</td> <td>Atique Salmani</td> <td>New</td> <td></td> <td>-</td> </tr> <tr> <td>11-10-2022 11:34:29</td> <td>Atique Salmani</td> <td>New</td> <td></td> <td>-</td> </tr> </tbody> </table>					Date Time	Technician Name	Status	Remark	Sign	11-10-2022 01:01:48	Atique Salmani	Completed	checked w.l.d. system by water dropping and also it's hootring working ok zo e healthy an all lamps test working ok.		11-10-2022 11:35:47	Atique Salmani	New		-	11-10-2022 11:34:29	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																					
11-10-2022 01:01:48	Atique Salmani	Completed	checked w.l.d. system by water dropping and also it's hootring working ok zo e healthy an all lamps test working ok.																						
11-10-2022 11:35:47	Atique Salmani	New		-																					
11-10-2022 11:34:29	Atique Salmani	New		-																					
Previous Complain History :	<table border="1"> <thead> <tr> <th>Date Time</th> <th>Technician Name</th> <th>Remark</th> </tr> </thead> <tbody> <tr> <td>24-05-2022 10:18:43</td> <td>Atique Salmani</td> <td>check water leak detector panel all connections ok and also check by water dropping on zone iys hootring system healthy.</td> </tr> <tr> <td>15-04-2022 11:52:10</td> <td>Atique Salmani</td> <td>check wld system zone healthy it's working ok use SMPS for hooter becz pannel 12 volt output not giving so use saprate SMPS .</td> </tr> </tbody> </table>					Date Time	Technician Name	Remark	24-05-2022 10:18:43	Atique Salmani	check water leak detector panel all connections ok and also check by water dropping on zone iys hootring system healthy.	15-04-2022 11:52:10	Atique Salmani	check wld system zone healthy it's working ok use SMPS for hooter becz pannel 12 volt output not giving so use saprate SMPS .											
Date Time	Technician Name	Remark																							
24-05-2022 10:18:43	Atique Salmani	check water leak detector panel all connections ok and also check by water dropping on zone iys hootring system healthy.																							
15-04-2022 11:52:10	Atique Salmani	check wld system zone healthy it's working ok use SMPS for hooter becz pannel 12 volt output not giving so use saprate SMPS .																							