




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE9399																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	8796230983																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	AMC visiting	Date & Time :	04-09-2023 11:36:54																	
Vendor Details :																				
Company Name/Client Name :	Secure Debt Management Consultants Llp	Customer's Mobile :	8796230983	Name :	Gaurav Kulkarni															
Address :																				
Mumbai , , , 400031 , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Ppm																			
Complain :	WLD PPM Need to do																			
Technician Comment :	Water leak detector pannel check Zone chek by manually And all connections in pannel chek working ok Pannel working on health condition.																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Water leak detector pannel check Zone chek by manually And all connections in pannel chek working ok Pannel working on health condition.																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>04-09-2023 02:49:54</td><td>Atique Salmani</td><td>Completed</td><td>Water leak detector pannel check Zone chek by manually And all connections in pannel chek working ok Pannel working on health condition.</td><td></td></tr><tr><td>04-09-2023 11:37:00</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	04-09-2023 02:49:54	Atique Salmani	Completed	Water leak detector pannel check Zone chek by manually And all connections in pannel chek working ok Pannel working on health condition.		04-09-2023 11:37:00	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
04-09-2023 02:49:54	Atique Salmani	Completed	Water leak detector pannel check Zone chek by manually And all connections in pannel chek working ok Pannel working on health condition.																	
04-09-2023 11:37:00	Atique Salmani	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>15-04-2023 12:00:52</td><td>Atique Salmani</td><td>Water leak detection check manually it's working properly panel also healthy condition.</td></tr><tr><td>12-01-2023 02:50:20</td><td>Atique Salmani</td><td>Water leak detector testing hooter also working when sence water leakage . Pannel working on healthy condition.</td></tr></tbody></table>					Date Time	Technician Name	Remark	15-04-2023 12:00:52	Atique Salmani	Water leak detection check manually it's working properly panel also healthy condition.	12-01-2023 02:50:20	Atique Salmani	Water leak detector testing hooter also working when sence water leakage . Pannel working on healthy condition.						
Date Time	Technician Name	Remark																		
15-04-2023 12:00:52	Atique Salmani	Water leak detection check manually it's working properly panel also healthy condition.																		
12-01-2023 02:50:20	Atique Salmani	Water leak detector testing hooter also working when sence water leakage . Pannel working on healthy condition.																		