


# Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067  
Support : | W : www.vallabhenterprises.com  
E : vallabhsecure@yahoo.co.in

<b>Service Status Details : VE4256</b>					
<b>Priority :</b>	Low				
<b>Created By :</b>	Admin - Apurva Vajaria				
<b>Complaint Mob. No. :</b>	0235034308				
<b>Technician Name :</b>	Mayur Yadav		<b>Technician Mobile :</b>	8411951301	
<b>Ticket Type :</b>	Complain	<b>Date &amp; Time :</b>	20-11-2021 10:38:36		
<b>Vendor Details :</b>					
Company Name/Client Name :	Ventura Alloy Kandivali Site	Customer's Mobile :	0235034308	Name :	Ghanshayam Tower
<b>Address :</b>					
Mumbai , , , , Maharashtra					
<b>AMC Details :</b>					
Expiry Date :	01-01-1970 05:30:00		Type :		
<b>Product Name :</b>	CCTV				
<b>Complain :</b>	DVR Online need to do & 1 dvr live view need to do				
<b>Technician Comment :</b>	fire all sd cleaned and confrence room wrong connection remooved and do proper working ok check by smoke and also by MCP ok 5 door access checked working ok.and also epbax check all line ok . cctv need to changed network and bhiwandi ware house bandwidth issue so it's panding .				
<b>Complain Operator :</b>	Desktop - Apurva Vajaria				
<b>Remark :</b>	fire all sd cleaned and confrence room wrong connection remooved and do proper working ok check by smoke and also by MCP ok 5 door access checked working ok.and also epbax check all line ok . cctv need to changed network and bhiwandi ware house bandwidth issue so it's panding .				
<b>Status History :</b>	<b>Date Time</b>	<b>Technician Name</b>	<b>Status</b>	<b>Remark</b>	<b>Sign</b>
	20-11-2021 05:16:47	MayurYadav	New		-
	20-11-2021 02:28:04	MayurYadav	Work Pending	fire all sd cleaned and confrence room wrong connection remooved and do proper working ok check by smoke and also by MCP ok 5 door access checked working ok.and also epbax check all line ok . cctv need to changed network and bhiwandi ware house bandwidth issue so it's panding .	
	20-11-2021 10:38:48	MayurYadav	New		-
	20-11-2021 10:38:36	MayurYadav	New		-

<b>Previous Complain History :</b>			
	Date Time	Technician Name	Remark
	24-07-2023 11:54:28	Ravi Rajbhar	ppm done of cctv system , fire panal , epbax system and access all ok working done and TA software check network issue client side
	22-07-2023 10:23:12	Atique Salmani	Check recording total 15 days but 1 to 20 not record from 21 to 22 available only keep hdd on overwrite and also formatted hdd after permission Deepika ma and keep on under observation.