

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE8168																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	0235034308																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	AMC visiting	Date & Time :	20-04-2023 12:23:15																	
Vendor Details :																				
Company Name/Client Name :	Ventura Alloy Kandivali Site	Customer's Mobile :	0235034308	Name :	Ghanshayam Tower															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Ppm																			
Complain :	cctv / fire / access / epabx PPM Need to do																			
Technician Comment :	Cctv fire door lock access epbax ppm done and ch cknall door s and fire manually by mcp Cctv check regarding hdd bad sector all ok only bhivandi cameras offline due to some power consumption.																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Cctv fire door lock access epbax ppm done and ch cknall door s and fire manually by mcp Cctv check regarding hdd bad sector all ok only bhivandi cameras offline due to some power consumption.																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>20-04-2023 04:35:28</td><td>Atique Salmani</td><td>Completed</td><td>Cctv fire door lock access epbax ppm done and ch cknall door s and fire manually by mcp Cctv check regarding hdd bad sector all ok only bhivandi cameras offline due to some power consumption.</td><td></td></tr><tr><td>20-04-2023 12:23:22</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	20-04-2023 04:35:28	Atique Salmani	Completed	Cctv fire door lock access epbax ppm done and ch cknall door s and fire manually by mcp Cctv check regarding hdd bad sector all ok only bhivandi cameras offline due to some power consumption.		20-04-2023 12:23:22	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
20-04-2023 04:35:28	Atique Salmani	Completed	Cctv fire door lock access epbax ppm done and ch cknall door s and fire manually by mcp Cctv check regarding hdd bad sector all ok only bhivandi cameras offline due to some power consumption.																	
20-04-2023 12:23:22	Atique Salmani	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>27-04-2023 04:54:58</td><td>Prashant Nikalje</td><td></td></tr><tr><td>18-04-2023 10:50:49</td><td>MayurYadav</td><td>jio router port forwarding settings to be done by jio engineer for office NVR ip 192.168.1.150 port 8000 and 81 Bhivandi camera online in mobile</td></tr></tbody></table>					Date Time	Technician Name	Remark	27-04-2023 04:54:58	Prashant Nikalje		18-04-2023 10:50:49	MayurYadav	jio router port forwarding settings to be done by jio engineer for office NVR ip 192.168.1.150 port 8000 and 81 Bhivandi camera online in mobile						
Date Time	Technician Name	Remark																		
27-04-2023 04:54:58	Prashant Nikalje																			
18-04-2023 10:50:49	MayurYadav	jio router port forwarding settings to be done by jio engineer for office NVR ip 192.168.1.150 port 8000 and 81 Bhivandi camera online in mobile																		