




# Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067  
Support : | W : www.vallabhenterprises.com  
E : vallabhsecure@yahoo.co.in

<b>Service Status Details : VE11526</b>																				
<b>Priority :</b>	Low																			
<b>Created By :</b>	Admin - Apurva Vajaria																			
<b>Complaint Mob. No. :</b>	8451099978																			
<b>Technician Name :</b>	Atique Salmani		<b>Technician Mobile :</b>	8080922984																
<b>Ticket Type :</b>	AMC visiting	<b>Date &amp; Time :</b>	30-04-2024 10:31:00																	
<b>Vendor Details :</b>																				
Company Name/Client Name :	Dev Research Centre	Customer's Mobile :	8451099978	Name :	Hitesh Doshi															
<b>Address :</b>																				
Mumbai , , , , Maharashtra																				
<b>AMC Details :</b>																				
Expiry Date :	06-06-2021 12:00:00		Type :	Comprehensive																
<b>Product Name :</b>	Ppm																			
<b>Complain :</b>	Access / EPABX / Fire PPM need to do																			
<b>Technician Comment :</b>	All floor door access chek working ok and also smoke detectors chek all ok fire pannel chek by mcp chek all ok one intercom phone was issue so swap only phone .																			
<b>Complain Operator :</b>	Desktop - Apurva Vajaria																			
<b>Remark :</b>	All floor door access chek working ok and also smoke detectors chek all ok fire pannel chek by mcp chek all ok one intercom phone was issue so swap only phone .																			
<b>Status History :</b>	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>30-04-2024 01:13:31</td><td>Atique Salmani</td><td>Completed</td><td>All floor door access chek working ok and also smoke detectors chek all ok fire pannel chek by mcp chek all ok one intercom phone was issue so swap only phone .</td><td></td></tr><tr><td>30-04-2024 10:31:05</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	30-04-2024 01:13:31	Atique Salmani	Completed	All floor door access chek working ok and also smoke detectors chek all ok fire pannel chek by mcp chek all ok one intercom phone was issue so swap only phone .		30-04-2024 10:31:05	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
30-04-2024 01:13:31	Atique Salmani	Completed	All floor door access chek working ok and also smoke detectors chek all ok fire pannel chek by mcp chek all ok one intercom phone was issue so swap only phone .																	
30-04-2024 10:31:05	Atique Salmani	New		-																
<b>Previous Complain History :</b>	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>29-04-2024 03:58:45</td><td>Atique Salmani</td><td>Archiv door access issue resolved there is one SMPS was off so it was not working also shown to Jagdish ji electrician.</td></tr><tr><td>31-01-2024 12:14:44</td><td>Ravi Rajbhar</td><td>ppm done of access door, fire panal, and intercom check all ok working done and fire hooter not working all floor then check panal and reconnecting hooter then ok working done and 1st floor access issue resolved and ok working done and 3rd floor divice off then starts divice and ok working done</td></tr></tbody></table>					Date Time	Technician Name	Remark	29-04-2024 03:58:45	Atique Salmani	Archiv door access issue resolved there is one SMPS was off so it was not working also shown to Jagdish ji electrician.	31-01-2024 12:14:44	Ravi Rajbhar	ppm done of access door, fire panal, and intercom check all ok working done and fire hooter not working all floor then check panal and reconnecting hooter then ok working done and 1st floor access issue resolved and ok working done and 3rd floor divice off then starts divice and ok working done						
Date Time	Technician Name	Remark																		
29-04-2024 03:58:45	Atique Salmani	Archiv door access issue resolved there is one SMPS was off so it was not working also shown to Jagdish ji electrician.																		
31-01-2024 12:14:44	Ravi Rajbhar	ppm done of access door, fire panal, and intercom check all ok working done and fire hooter not working all floor then check panal and reconnecting hooter then ok working done and 1st floor access issue resolved and ok working done and 3rd floor divice off then starts divice and ok working done																		