


Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE14347					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	8451099978				
Technician Name :	Yogesh Desai		Technician Mobile :	8080922963	
Ticket Type :	Complain	Date & Time :	22-03-2025 06:29:54		
Vendor Details :					
Company Name/Client Name :	Dev Research Centre	Customer's Mobile :	8451099978	Name :	Hitesh Doshi
Address :					
Mumbai , , , , Maharashtra					
AMC Details :					
Expiry Date :	06-06-2021 12:00:00		Type :	Comprehensive	
Product Name :	Access				
Complain :	2 lab door access issue				
Technician Comment :	Ground floor access door and third floor access door were open by MCP therefore all lab doors of ground and 3 floor lab were open. Now after chking doors are closed by closing the MCP unrelased All lab doors of ground and third floor are closed properly and can be open by biometric device only.				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	Ground floor access door and third floor access door were open by MCP therefore all lab doors of ground and 3 floor lab were open. Now after chking doors are closed by closing the MCP unrelased All lab doors of ground and third floor are closed properly and can be open by biometric device only.				
Status History :	Date Time	Technician Name	Status	Remark	Sign
	24-03-2025 04:03:18	YogeshDesai	Completed	Ground floor access door and third floor access door were open by MCP therefore all lab doors of ground and 3 floor lab were open. Now after chking doors are closed by closing the MCP unrelased All lab doors of ground and third floor are closed properly and can be open by biometric device only.	
	22-03-2025 06:30:01	YogeshDesai	New		-
Previous Complain History :	Date Time	Technician Name	Remark		
	13-06-2025 11:25:49	Rahul Mhapralkar	3rd floor access machine installed working normally		
	03-06-2025 11:53:47	Neeraj Chauhan	Lock issue solved lock working okk manual lock issue		