




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE4704																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	8451099978																								
Technician Name :	Siddhesh Chavan		Technician Mobile :	8080922985																					
Ticket Type :	Complain	Date & Time :	04-02-2022 10:29:01																						
Vendor Details :																									
Company Name/Client Name :	Dev Research Centre	Customer's Mobile :	8451099978	Name :	Hitesh Doshi																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	06-06-2021 12:00:00		Type :	Comprehensive																					
Product Name :	Ppm																								
Complain :	Access/EPABX/Fire																								
Technician Comment :	PPM work of Acess , Fire, Epbax done All smoke detector cleaned . and also all door acces checked MCP , hooter fire test done. intercom system working ok all line working ok. 2) 1 st floor biometric machines take to office for checking and finger sensor not working																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	PPM work of Acess , Fire, Epbax done All smoke detector cleaned . and also all door acces checked MCP , hooter fire test done. intercom system working ok all line working ok. 2) 1 st floor biometric machines take to office for checking and finger sensor not working																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>04-02-2022 05:19:57</td><td>Siddhesh Chavan</td><td>Completed</td><td>PPM work of Acess , Fire, Epbax done All smoke detector cleaned . and also all door acces checked MCP , hooter fire test done. intercom system working ok all line working ok. 2) 1 st floor biometric machines take to office for checking and finger sensor not working</td><td></td></tr><tr><td>04-02-2022 10:29:24</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr><tr><td>04-02-2022 10:29:01</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	04-02-2022 05:19:57	Siddhesh Chavan	Completed	PPM work of Acess , Fire, Epbax done All smoke detector cleaned . and also all door acces checked MCP , hooter fire test done. intercom system working ok all line working ok. 2) 1 st floor biometric machines take to office for checking and finger sensor not working		04-02-2022 10:29:24	Siddhesh Chavan	New		-	04-02-2022 10:29:01	Siddhesh Chavan	New		-
Date Time	Technician Name	Status	Remark	Sign																					
04-02-2022 05:19:57	Siddhesh Chavan	Completed	PPM work of Acess , Fire, Epbax done All smoke detector cleaned . and also all door acces checked MCP , hooter fire test done. intercom system working ok all line working ok. 2) 1 st floor biometric machines take to office for checking and finger sensor not working																						
04-02-2022 10:29:24	Siddhesh Chavan	New		-																					
04-02-2022 10:29:01	Siddhesh Chavan	New		-																					

Previous Complain History :	Date Time	Technician Name	Remark
	19-02-2022 12:32:29	Ravi Rajbhar	fire panel hooter replace and ok working done main gate and biometric attendance issue all data clear old new 17 porson add in divice and data download ok working software
	19-02-2022 10:18:22	Ravi Rajbhar	essl access control terminal device repair return with install all ok working done and security cabin fire panel 2 zone check all ok working done