







Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE4823																																			
Priority :	Low																																		
Created By :	Admin - Apurva Vajaria																																		
Complaint Mob. No. :	8451099978																																		
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																															
Ticket Type :	Complain	Date & Time :	19-02-2022 12:32:29																																
Vendor Details :																																			
Company Name/Client Name :	Dev Research Centre	Customer's Mobile :	8451099978	Name :	Hitesh Doshi																														
Address :																																			
Mumbai , , , , Maharashtra																																			
AMC Details :																																			
Expiry Date :	06-06-2021 12:00:00		Type :	Comprehensive																															
Product Name :	Fire																																		
Complain :	fire alarm issue																																		
Technician Comment :	fire panel hooter replace and ok working done main gate and biometric attendance issue all data clear old new 17 porson add in divice and data download ok working software																																		
Complain Operator :	Desktop - Apurva Vajaria																																		
Remark :	fire panel hooter replace and ok working done main gate and biometric attendance issue all data clear old new 17 porson add in divice and data download ok working software																																		
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>21-02-2022 01:22:49</td><td>Ravi Rajbhar</td><td>Completed</td><td>fire panel hooter replace and ok working done main gate and biometric attendance issue all data clear old new 17 porson add in divice and data download ok working software</td><td></td></tr><tr><td>21-02-2022 10:23:03</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr><tr><td>19-02-2022 02:12:06</td><td>Ravi Rajbhar</td><td>Work Pending</td><td>fire panel check and ok working done all zone but main gate hooter faulty and remove faulty hooter hondover to security Guard and security cabin hooter swap confirm to Dr. bk sharam sir</td><td></td></tr><tr><td>19-02-2022 12:32:43</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr><tr><td>19-02-2022 12:32:29</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	21-02-2022 01:22:49	Ravi Rajbhar	Completed	fire panel hooter replace and ok working done main gate and biometric attendance issue all data clear old new 17 porson add in divice and data download ok working software		21-02-2022 10:23:03	Ravi Rajbhar	New		-	19-02-2022 02:12:06	Ravi Rajbhar	Work Pending	fire panel check and ok working done all zone but main gate hooter faulty and remove faulty hooter hondover to security Guard and security cabin hooter swap confirm to Dr. bk sharam sir		19-02-2022 12:32:43	Ravi Rajbhar	New		-	19-02-2022 12:32:29	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																															
21-02-2022 01:22:49	Ravi Rajbhar	Completed	fire panel hooter replace and ok working done main gate and biometric attendance issue all data clear old new 17 porson add in divice and data download ok working software																																
21-02-2022 10:23:03	Ravi Rajbhar	New		-																															
19-02-2022 02:12:06	Ravi Rajbhar	Work Pending	fire panel check and ok working done all zone but main gate hooter faulty and remove faulty hooter hondover to security Guard and security cabin hooter swap confirm to Dr. bk sharam sir																																
19-02-2022 12:32:43	Ravi Rajbhar	New		-																															
19-02-2022 12:32:29	Ravi Rajbhar	New		-																															

Previous Complain History :	Date Time	Technician Name	Remark
	19-02-2022 10:18:22	Ravi Rajbhar	essl access control terminal device repair return with install all ok working done and security cabin fire panel 2 zone check all ok working done
	04-02-2022 10:29:01	Siddhesh Chavan	PPM work of Access , Fire, Epbax done All smoke detector cleaned . and also all door acces checked MCP , hooter fire test done. intercom system working ok all line working ok. 2) 1 st floor biometric machines take to office for checking and finger sensor not working