




# Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067  
Support : | W : www.vallabhenterprises.com  
E : vallabhsecure@yahoo.co.in

<b>Service Status Details : VE5561</b>																									
<b>Priority :</b>	Low																								
<b>Created By :</b>	Admin - Apurva Vajaria																								
<b>Complaint Mob. No. :</b>	8451099978																								
<b>Technician Name :</b>	Mayur Yadav		<b>Technician Mobile :</b>	8411951301																					
<b>Ticket Type :</b>	Complain	<b>Date &amp; Time :</b>	26-05-2022 10:51:15																						
<b>Vendor Details :</b>																									
Company Name/Client Name :	Dev Research Centre	Customer's Mobile :	8451099978	Name :	Hitesh Doshi																				
<b>Address :</b>																									
Mumbai , , , , Maharashtra																									
<b>AMC Details :</b>																									
Expiry Date :	06-06-2021 12:00:00		Type :	Comprehensive																					
<b>Product Name :</b>	Fire																								
<b>Complain :</b>	The fire alarm on the ground floor is malfunctioning as it keeps giving out false alarm																								
<b>Technician Comment :</b>	heat detector check, clean and swipe security cabin hooter connect only in security cabin fire panel not integrate with main building fire panel																								
<b>Complain Operator :</b>	Desktop - Apurva Vajaria																								
<b>Remark :</b>	heat detector check, clean and swipe security cabin hooter connect only in security cabin fire panel not integrate with main building fire panel																								
<b>Status History :</b>	<table border="1"> <thead> <tr> <th>Date Time</th> <th>Technician Name</th> <th>Status</th> <th>Remark</th> <th>Sign</th> </tr> </thead> <tbody> <tr> <td>26-05-2022 10:54:46</td> <td>MayurYadav</td> <td>Completed</td> <td>heat detector check, clean and swipe security cabin hooter connect only in security cabin fire panel not integrate with main building fire panel</td> <td></td> </tr> <tr> <td>26-05-2022 10:51:34</td> <td>MayurYadav</td> <td>New</td> <td></td> <td>-</td> </tr> <tr> <td>26-05-2022 10:51:15</td> <td>MayurYadav</td> <td>New</td> <td></td> <td>-</td> </tr> </tbody> </table>					Date Time	Technician Name	Status	Remark	Sign	26-05-2022 10:54:46	MayurYadav	Completed	heat detector check, clean and swipe security cabin hooter connect only in security cabin fire panel not integrate with main building fire panel		26-05-2022 10:51:34	MayurYadav	New		-	26-05-2022 10:51:15	MayurYadav	New		-
Date Time	Technician Name	Status	Remark	Sign																					
26-05-2022 10:54:46	MayurYadav	Completed	heat detector check, clean and swipe security cabin hooter connect only in security cabin fire panel not integrate with main building fire panel																						
26-05-2022 10:51:34	MayurYadav	New		-																					
26-05-2022 10:51:15	MayurYadav	New		-																					
<b>Previous Complain History :</b>	<table border="1"> <thead> <tr> <th>Date Time</th> <th>Technician Name</th> <th>Remark</th> </tr> </thead> <tbody> <tr> <td>23-05-2022 10:13:06</td> <td>Siddhesh Chavan</td> <td>all access working okay biometric working okay epbx system working OK all line working fire first zone open issue resolve and all smoke detector clean and all hooters working OK and 2 panel working okay</td> </tr> <tr> <td>25-04-2022 10:28:22</td> <td>Atique Salmani</td> <td>installed biometric device and working ok and also add 3/4 employees fingers thumb and index and also told to Harsha mam how to add employees and working ok lock aslo losse done it proper.make our admin 3107 3107.</td> </tr> </tbody> </table>					Date Time	Technician Name	Remark	23-05-2022 10:13:06	Siddhesh Chavan	all access working okay biometric working okay epbx system working OK all line working fire first zone open issue resolve and all smoke detector clean and all hooters working OK and 2 panel working okay	25-04-2022 10:28:22	Atique Salmani	installed biometric device and working ok and also add 3/4 employees fingers thumb and index and also told to Harsha mam how to add employees and working ok lock aslo losse done it proper.make our admin 3107 3107.											
Date Time	Technician Name	Remark																							
23-05-2022 10:13:06	Siddhesh Chavan	all access working okay biometric working okay epbx system working OK all line working fire first zone open issue resolve and all smoke detector clean and all hooters working OK and 2 panel working okay																							
25-04-2022 10:28:22	Atique Salmani	installed biometric device and working ok and also add 3/4 employees fingers thumb and index and also told to Harsha mam how to add employees and working ok lock aslo losse done it proper.make our admin 3107 3107.																							