

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE7621																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	8451099978																			
Technician Name :	Chandan Yadav		Technician Mobile :	9833262842																
Ticket Type :	Complain	Date & Time :	13-02-2023 02:46:16																	
Vendor Details :																				
Company Name/Client Name :	Dev Research Centre	Customer's Mobile :	8451099978	Name :	Hitesh Doshi															
Address :																				
Mumbai , , , Maharashtra																				
AMC Details :																				
Expiry Date :	06-06-2021 12:00:00		Type :	Comprehensive																
Product Name :	Fire																			
Complain :	False alarm issue																			
Technician Comment :	Fair alarm system working ok																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Fair alarm system working ok																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>13-02-2023 04:02:41</td><td>ChandanYadav</td><td>Completed</td><td>Fair alarm system working ok</td><td></td></tr><tr><td>13-02-2023 02:46:24</td><td>ChandanYadav</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	13-02-2023 04:02:41	ChandanYadav	Completed	Fair alarm system working ok		13-02-2023 02:46:24	ChandanYadav	New		-
Date Time	Technician Name	Status	Remark	Sign																
13-02-2023 04:02:41	ChandanYadav	Completed	Fair alarm system working ok																	
13-02-2023 02:46:24	ChandanYadav	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>08-02-2023 10:02:04</td><td>Ravi Rajbhar</td><td>Ppm done of fire panel, access door, epbax all system ok working done 3rd floor main door access device of client side confrim to pradeep sir Security cabin fire panel check battery low</td></tr><tr><td>28-01-2023 01:27:49</td><td>Prashant Nikalje</td><td>Biomax power supply faulty resolved and solved new power supply install faulty supply collect in office</td></tr></tbody></table>					Date Time	Technician Name	Remark	08-02-2023 10:02:04	Ravi Rajbhar	Ppm done of fire panel, access door, epbax all system ok working done 3rd floor main door access device of client side confrim to pradeep sir Security cabin fire panel check battery low	28-01-2023 01:27:49	Prashant Nikalje	Biomax power supply faulty resolved and solved new power supply install faulty supply collect in office						
Date Time	Technician Name	Remark																		
08-02-2023 10:02:04	Ravi Rajbhar	Ppm done of fire panel, access door, epbax all system ok working done 3rd floor main door access device of client side confrim to pradeep sir Security cabin fire panel check battery low																		
28-01-2023 01:27:49	Prashant Nikalje	Biomax power supply faulty resolved and solved new power supply install faulty supply collect in office																		