




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE9512																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	8451099978																			
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																
Ticket Type :	Complain	Date & Time :	12-09-2023 11:25:36																	
Vendor Details :																				
Company Name/Client Name :	Dev Research Centre	Customer's Mobile :	8451099978	Name :	Hitesh Doshi															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	06-06-2021 12:00:00		Type :	Comprehensive																
Product Name :	EPABX																			
Complain :	Some epabx extensions change issue																			
Technician Comment :	all ex. number check allready ok working done all ex.no. and only password change Admin@123 ip 192.168.1.101																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	all ex. number check allready ok working done all ex.no. and only password change Admin@123 ip 192.168.1.101																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>14-09-2023 05:19:50</td><td>Ravi Rajbhar</td><td>Completed</td><td>all ex. number check allready ok working done all ex.no. and only password change Admin@123 ip 192.168.1.101</td><td></td></tr><tr><td>14-09-2023 10:13:56</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	14-09-2023 05:19:50	Ravi Rajbhar	Completed	all ex. number check allready ok working done all ex.no. and only password change Admin@123 ip 192.168.1.101		14-09-2023 10:13:56	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																
14-09-2023 05:19:50	Ravi Rajbhar	Completed	all ex. number check allready ok working done all ex.no. and only password change Admin@123 ip 192.168.1.101																	
14-09-2023 10:13:56	Ravi Rajbhar	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>31-08-2023 10:28:49</td><td>Munna Gupta</td><td>All floor smoke detectors clean and all floor door access checked and intercom also checked there is instrument issue 113/109/dvr rrom 2nd floor one cabin and checked by mcp press all floor hootring and ground floor security cabin fire hooter and battery issue so collect and set date and time in biometric devices .ppm work completed hooter n battery painding security cabin main gate .</td></tr><tr><td>11-08-2023 12:04:04</td><td>DilshadKhan</td><td>1st foolr door access devise machine installed after repair working ok.</td></tr></tbody></table>					Date Time	Technician Name	Remark	31-08-2023 10:28:49	Munna Gupta	All floor smoke detectors clean and all floor door access checked and intercom also checked there is instrument issue 113/109/dvr rrom 2nd floor one cabin and checked by mcp press all floor hootring and ground floor security cabin fire hooter and battery issue so collect and set date and time in biometric devices .ppm work completed hooter n battery painding security cabin main gate .	11-08-2023 12:04:04	DilshadKhan	1st foolr door access devise machine installed after repair working ok.						
Date Time	Technician Name	Remark																		
31-08-2023 10:28:49	Munna Gupta	All floor smoke detectors clean and all floor door access checked and intercom also checked there is instrument issue 113/109/dvr rrom 2nd floor one cabin and checked by mcp press all floor hootring and ground floor security cabin fire hooter and battery issue so collect and set date and time in biometric devices .ppm work completed hooter n battery painding security cabin main gate .																		
11-08-2023 12:04:04	DilshadKhan	1st foolr door access devise machine installed after repair working ok.																		