







Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE9569																														
Priority :	Low																													
Created By :	Admin - Apurva Vajaria																													
Complaint Mob. No. :	8451099978																													
Technician Name :	Munna Gupta		Technician Mobile :	8080922982																										
Ticket Type :	Complain	Date & Time :	18-09-2023 11:34:59																											
Vendor Details :																														
Company Name/Client Name :	Dev Research Centre	Customer's Mobile :	8451099978	Name :	Hitesh Doshi																									
Address :																														
Mumbai , , , , Maharashtra																														
AMC Details :																														
Expiry Date :	06-06-2021 12:00:00		Type :	Comprehensive																										
Product Name :	Fire																													
Complain :	Fire Alarm Panel continuously given a voice of siren. which is installed on the ground floor of our R&D Centre. reset the panel several times, but within 5 seconds, siren is sounding.																													
Technician Comment :	One smoke detector installation complete working properly.																													
Complain Operator :	Desktop - Apurva Vajaria																													
Remark :	One smoke detector installation complete working properly.																													
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>23-09-2023 03:30:31</td><td>Munna Gupta</td><td>Completed</td><td>One smoke detector installation complete working properly.</td><td></td></tr><tr><td>23-09-2023 12:54:44</td><td>Munna Gupta</td><td>New</td><td></td><td>-</td></tr><tr><td>18-09-2023 03:20:34</td><td>Munna Gupta</td><td>Work Pending</td><td>Ground floor GIp test facility S.D.faulty it's going again an again on fire so for check swap s.d.from store room it's working so now we have to changed smoke detectors store room and loop by pass paneel all zone working healthy condition.</td><td></td></tr><tr><td>18-09-2023 11:35:05</td><td>Munna Gupta</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	23-09-2023 03:30:31	Munna Gupta	Completed	One smoke detector installation complete working properly.		23-09-2023 12:54:44	Munna Gupta	New		-	18-09-2023 03:20:34	Munna Gupta	Work Pending	Ground floor GIp test facility S.D.faulty it's going again an again on fire so for check swap s.d.from store room it's working so now we have to changed smoke detectors store room and loop by pass paneel all zone working healthy condition.		18-09-2023 11:35:05	Munna Gupta	New		-
Date Time	Technician Name	Status	Remark	Sign																										
23-09-2023 03:30:31	Munna Gupta	Completed	One smoke detector installation complete working properly.																											
23-09-2023 12:54:44	Munna Gupta	New		-																										
18-09-2023 03:20:34	Munna Gupta	Work Pending	Ground floor GIp test facility S.D.faulty it's going again an again on fire so for check swap s.d.from store room it's working so now we have to changed smoke detectors store room and loop by pass paneel all zone working healthy condition.																											
18-09-2023 11:35:05	Munna Gupta	New		-																										

Previous Complain History :			
	Date Time	Technician Name	Remark
	26-09-2023 10:45:43	Ravi Rajbhar	epbax systam check and ex.number changeing issue resloved ans ok working done but Under observation
	12-09-2023 11:25:36	Ravi Rajbhar	all ex. number check allready ok working done all ex.no. and only password change Admin@123 ip 192.168.1.101