

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE9340																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9820606496																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	Complain	Date & Time :	31-08-2023 10:26:12																	
Vendor Details :																				
Company Name/Client Name :	Skylone	Customer's Mobile :	9820606496	Name :	Irani Wadi															
Address :																				
Mumbai , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	VDP																			
Complain :	B-1703 - 8369294090 - when bell press short bell ringing but nothing is visible on the camera																			
Technician Comment :	18 floor duct side power supply off plug point remooved by someone no w working ok.																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	18 floor duct side power supply off plug point remooved by someone no w working ok.																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>31-08-2023 05:57:17</td><td>Atique Salmani</td><td>Completed</td><td>18 floor duct side power supply off plug point remooved by someone no w working ok.</td><td></td></tr><tr><td>31-08-2023 04:44:34</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	31-08-2023 05:57:17	Atique Salmani	Completed	18 floor duct side power supply off plug point remooved by someone no w working ok.		31-08-2023 04:44:34	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
31-08-2023 05:57:17	Atique Salmani	Completed	18 floor duct side power supply off plug point remooved by someone no w working ok.																	
31-08-2023 04:44:34	Atique Salmani	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>01-09-2023 12:56:23</td><td>Siddhesh Chavan</td><td>b wing 10 th floor all flats lobby video issue resoved and 9 th floor pow supply off and re on supply and working OK</td></tr><tr><td>31-08-2023 02:15:00</td><td>Siddhesh Chavan</td><td>vdp working OK and lobby video working OK</td></tr></tbody></table>					Date Time	Technician Name	Remark	01-09-2023 12:56:23	Siddhesh Chavan	b wing 10 th floor all flats lobby video issue resoved and 9 th floor pow supply off and re on supply and working OK	31-08-2023 02:15:00	Siddhesh Chavan	vdp working OK and lobby video working OK						
Date Time	Technician Name	Remark																		
01-09-2023 12:56:23	Siddhesh Chavan	b wing 10 th floor all flats lobby video issue resoved and 9 th floor pow supply off and re on supply and working OK																		
31-08-2023 02:15:00	Siddhesh Chavan	vdp working OK and lobby video working OK																		