

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE8981																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9920420594																								
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																					
Ticket Type :	AMC visiting	Date & Time :	26-07-2023 01:44:45																						
Vendor Details :																									
Company Name/Client Name :	Matunga Kamal Kunj Society	Customer's Mobile :	9920420594	Name :	Jayprakash Kiran Sir Joy																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Ppm																								
Complain :	CCTV/VDP/Access Control System/Time and Attendance																								
Technician Comment :	ppm done of cctv systam , access , video door phone and time attendance camplint - 1702 video door phone not working check our side but need to change poe enjector 48 volt and recoding check 26/ 7/23 to 26/7/23																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	ppm done of cctv systam , access , video door phone and time attendance camplint - 1702 video door phone not working check our side but need to change poe enjector 48 volt and recoding check 26/ 7/23 to 26/7/23																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>26-07-2023 04:49:20</td><td>Ravi Rajbhar</td><td>Completed</td><td>ppm done of cctv systam , access , video door phone and time attendance camplint - 1702 video door phone not working check our side but need to change poe enjector 48 volt and recoding check 26/ 7/23 to 26/7/23</td><td></td></tr><tr><td>26-07-2023 02:30:39</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr><tr><td>26-07-2023 01:44:54</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	26-07-2023 04:49:20	Ravi Rajbhar	Completed	ppm done of cctv systam , access , video door phone and time attendance camplint - 1702 video door phone not working check our side but need to change poe enjector 48 volt and recoding check 26/ 7/23 to 26/7/23		26-07-2023 02:30:39	Ravi Rajbhar	New		-	26-07-2023 01:44:54	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																					
26-07-2023 04:49:20	Ravi Rajbhar	Completed	ppm done of cctv systam , access , video door phone and time attendance camplint - 1702 video door phone not working check our side but need to change poe enjector 48 volt and recoding check 26/ 7/23 to 26/7/23																						
26-07-2023 02:30:39	Ravi Rajbhar	New		-																					
26-07-2023 01:44:54	Ravi Rajbhar	New		-																					

Previous Complain History :			
	Date Time	Technician Name	Remark
	22-08-2023 10:41:31	Ravi Rajbhar	recoding check and show to client 20/21/22 night 8pm to 12:00 pm and two camera off issue resloved only camra side rj 45 connector change
	19-06-2023 10:59:50	MayurYadav	Vdp install in 802 12 volt power supply use for out door camera Working ok