

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE12255					
Priority :	Low				
Created By :	Admin - Apurva Vajaria				
Complaint Mob. No. :	7400084949				
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965	
Ticket Type :	AMC visiting	Date & Time :	27-07-2024 01:31:39		
Vendor Details :					
Company Name/Client Name :	JB Boda Dadar Site	Customer's Mobile :	7400084949	Name :	Jb Boda
Address :					
Mumbai , , , , Maharashtra					
AMC Details :					
Expiry Date :	01-01-1970 05:30:00		Type :		
Product Name :	Ppm				
Complain :	1)The Ruby 4th floor Fire PPM need to do 2) The Ruby Insurance & Reinsurance_ The Ruby 5th floor Fire PPM need to do				
Technician Comment :	ppm done of fire alarm 4 th floor all smoke detectors clean and check hoter and mcp total detectors -20 5th floor all smoke detectors clean and ok working done total smoke detectors - 40				
Complain Operator :	Desktop - Apurva Vajaria				
Remark :	ppm done of fire alarm 4 th floor all smoke detectors clean and check hoter and mcp total detectors -20 5th floor all smoke detectors clean and ok working done total smoke detectors - 40				
Status History :	Date Time	Technician Name	Status	Remark	Sign
	27-07-2024 02:13:42	Ravi Rajbhar	Completed	ppm done of fire alarm 4 th floor all smoke detectors clean and check hoter and mcp total detectors -20 5th floor all smoke detectors clean and ok working done total smoke detectors - 40	
	27-07-2024 01:31:50	Ravi Rajbhar	New		-
Previous Complain History :	Date Time	Technician Name	Remark		
	07-08-2024 02:01:18	Ravi Rajbhar	4th floor fire alarm issue resolved one smoke detectors fire show and smoke detector clean and ok working done (Sarver room)		
	13-07-2024 02:46:56	Atique Salmani			