

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE12370																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	7400084949																			
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																
Ticket Type :	Complain	Date & Time :	07-08-2024 02:01:18																	
Vendor Details :																				
Company Name/Client Name :	JB Boda Dadar Site	Customer's Mobile :	7400084949	Name :	Jb Boda															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Fire																			
Complain :	5th floor fire panel issue																			
Technician Comment :	4th floor fire alarm issue resolved one smoke detectors fire show and smoke detector clean and ok working done (Sarver room)																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	4th floor fire alarm issue resolved one smoke detectors fire show and smoke detector clean and ok working done (Sarver room)																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>09-08-2024 12:37:46</td><td>Ravi Rajbhar</td><td>Completed</td><td>4th floor fire alarm issue resolved one smoke detectors fire show and smoke detector clean and ok working done (Sarver room)</td><td></td></tr><tr><td>09-08-2024 12:30:03</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	09-08-2024 12:37:46	Ravi Rajbhar	Completed	4th floor fire alarm issue resolved one smoke detectors fire show and smoke detector clean and ok working done (Sarver room)		09-08-2024 12:30:03	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																
09-08-2024 12:37:46	Ravi Rajbhar	Completed	4th floor fire alarm issue resolved one smoke detectors fire show and smoke detector clean and ok working done (Sarver room)																	
09-08-2024 12:30:03	Ravi Rajbhar	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>27-07-2024 01:31:39</td><td>Ravi Rajbhar</td><td>ppm done of fire alarm 4 th floor all smoke detectors clean and check hoter and mcp total detectors -20 5th floor all smoke detectors clean and ok working done total smoke detectors - 40</td></tr><tr><td>13-07-2024 02:46:56</td><td>Atique Salmani</td><td></td></tr></tbody></table>					Date Time	Technician Name	Remark	27-07-2024 01:31:39	Ravi Rajbhar	ppm done of fire alarm 4 th floor all smoke detectors clean and check hoter and mcp total detectors -20 5th floor all smoke detectors clean and ok working done total smoke detectors - 40	13-07-2024 02:46:56	Atique Salmani							
Date Time	Technician Name	Remark																		
27-07-2024 01:31:39	Ravi Rajbhar	ppm done of fire alarm 4 th floor all smoke detectors clean and check hoter and mcp total detectors -20 5th floor all smoke detectors clean and ok working done total smoke detectors - 40																		
13-07-2024 02:46:56	Atique Salmani																			