Vallabh Enterprises

 $\label{eq:Regd.office:401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067 \\ \text{Support:} \mid \textbf{W}: www.vallabhenterprises.com \\ \textbf{E}: vallabhsecure@yahoo.co.in \\ \end{cases}$

| E . valiablisecure@yano | | | | | | |
|-----------------------------------|--|---------------------|---|---|------------|---------|
| Service Status Deta | ails: VE13890 | | | | | |
| Priority: | Low | | | | | |
| Created By: | Admin - Apurva Vajaria | | | | | |
| Complaint Mob. No. : | 7400084949 | | | | | |
| Technician Name | Siddhesh Chavan | | Technicia | nn Mobile : | 8080922985 | |
| Ticket Type : | Complain | Date & Time : | 22-01-2025 11:15:34 | | | |
| Vendor Details : | | | | | | • |
| Company Name/Client Name : | JB Boda Dadar Site | Customer's Mobile : | 74000849 |)49 | Name: | Jb Boda |
| Address : | | | | | | |
| Mumbai , , , , Maha | arashtra | | | | | |
| AMC Details : | | | | | | |
| Expiry Date : | 01-01-1970 05:30:00 | | Type: | | | |
| Product Name: | Fire | | | | | |
| Complain: | 5th floor fire panel some noise issue | | | | | |
| Technician Comment : | 5th floor fire panel normal no foulty working ok 5th floor All senior = 51 noc Hoter = 2 noc Mcp = 1 4th Somke senior = 23 Mcp = 1 Hoter = 1 | | | | | |
| Complain Operator : | Desktop - Apurva Vajaria | | | | | |
| Remark: | 5th floor fire panel normal no foulty working ok 5th floor All senior = 51 noc Hoter = 2 noc Mcp = 1 4th Somke senior = 23 Mcp = 1 Hoter =1 | | | | | |
| Status History : | Date Time | Technician Name | Status | Remark | | Sign |
| | 22-01-2025 04:13:51 | Siddhesh Chavan | Completed | 5th floor fire panel normal no foulty working ok 5th floor All senior = 51 noc Hoter = 2 noc Mcp = 1 4th Somke senior = 23 Mcp = 1 Hoter =1 | | Mahr |
| | 22-01-2025 11:15:41 | Siddhesh Chavan | New | | | - |
| Previous Complain History : | Date Time | Technician Name | Remark | | | |
| | 24-01-2025 11:15:53 | Ravi Rajbhar | 5th floor fire panal check all ok working done And 4th floor fire panal also check And 4th floor main door access door em lock allament issue resolved and ok working | | | |
| | 07-08-2024 02:01:18 | Ravi Rajbhar | 4th floor fire alarm issue resolved one smoke detectors fire show and smoke detector clean and ok working done (Sarver room) | | | |