




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE13916																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	7400084949																			
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																
Ticket Type :	Complain	Date & Time :	24-01-2025 11:15:53																	
Vendor Details :																				
Company Name/Client Name :	JB Boda Dadar Site	Customer's Mobile :	7400084949	Name :	Jb Boda															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Fire																			
Complain :	fire panel beep sound issue																			
Technician Comment :	5th floor fire panel check all ok working done And 4th floor fire panel also check And 4th floor main door access door em lock allament issue resolved and ok working																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	5th floor fire panel check all ok working done And 4th floor fire panel also check And 4th floor main door access door em lock allament issue resolved and ok working																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>24-01-2025 04:39:28</td><td>Ravi Rajbhar</td><td>Completed</td><td>5th floor fire panel check all ok working done And 4th floor fire panel also check And 4th floor main door access door em lock allament issue resolved and ok working</td><td></td></tr><tr><td>24-01-2025 11:16:09</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	24-01-2025 04:39:28	Ravi Rajbhar	Completed	5th floor fire panel check all ok working done And 4th floor fire panel also check And 4th floor main door access door em lock allament issue resolved and ok working		24-01-2025 11:16:09	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																
24-01-2025 04:39:28	Ravi Rajbhar	Completed	5th floor fire panel check all ok working done And 4th floor fire panel also check And 4th floor main door access door em lock allament issue resolved and ok working																	
24-01-2025 11:16:09	Ravi Rajbhar	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>22-01-2025 11:15:34</td><td>Siddhesh Chavan</td><td>5th floor fire panel normal no faulty working ok 5th floor All senior = 51 noc Hoter = 2 noc Mcp = 1 4th Somke senior = 23 Mcp = 1 Hoter =1</td></tr><tr><td>07-08-2024 02:01:18</td><td>Ravi Rajbhar</td><td>4th floor fire alarm issue resolved one smoke detectors fire show and smoke detector clean and ok working done (Sarver room)</td></tr></tbody></table>					Date Time	Technician Name	Remark	22-01-2025 11:15:34	Siddhesh Chavan	5th floor fire panel normal no faulty working ok 5th floor All senior = 51 noc Hoter = 2 noc Mcp = 1 4th Somke senior = 23 Mcp = 1 Hoter =1	07-08-2024 02:01:18	Ravi Rajbhar	4th floor fire alarm issue resolved one smoke detectors fire show and smoke detector clean and ok working done (Sarver room)						
Date Time	Technician Name	Remark																		
22-01-2025 11:15:34	Siddhesh Chavan	5th floor fire panel normal no faulty working ok 5th floor All senior = 51 noc Hoter = 2 noc Mcp = 1 4th Somke senior = 23 Mcp = 1 Hoter =1																		
07-08-2024 02:01:18	Ravi Rajbhar	4th floor fire alarm issue resolved one smoke detectors fire show and smoke detector clean and ok working done (Sarver room)																		