

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE14686																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	7400084949																			
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																
Ticket Type :	Complain	Date & Time :	08-05-2025 10:58:24																	
Vendor Details :																				
Company Name/Client Name :	JB Boda Dadar Site	Customer's Mobile :	7400084949	Name :	Jb Boda															
Address :																				
Mumbai , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Fire																			
Complain :	5th floor Fire system beep sound issue																			
Technician Comment :	Chek fire pannel 10 d ups detector base issue need to chek and keep under observation for cheking .																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Chek fire pannel 10 d ups detector base issue need to chek and keep under observation for cheking .																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>08-05-2025 03:58:40</td><td>Atique Salmani</td><td>Work Pending</td><td>Chek fire pannel 10 d ups detector base issue need to chek and keep under observation for cheking .</td><td></td></tr><tr><td>08-05-2025 10:58:29</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	08-05-2025 03:58:40	Atique Salmani	Work Pending	Chek fire pannel 10 d ups detector base issue need to chek and keep under observation for cheking .		08-05-2025 10:58:29	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																
08-05-2025 03:58:40	Atique Salmani	Work Pending	Chek fire pannel 10 d ups detector base issue need to chek and keep under observation for cheking .																	
08-05-2025 10:58:29	Atique Salmani	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>16-07-2025 10:15:16</td><td>Ravi Rajbhar</td><td>Biometric attendance divice issue resolved and ok working done check reader connection and divice seting with same employees card re add to divice</td></tr><tr><td>10-07-2025 10:41:07</td><td>Siddhesh Chavan</td><td>4th floor fire panel battery issue need to change battery</td></tr></tbody></table>					Date Time	Technician Name	Remark	16-07-2025 10:15:16	Ravi Rajbhar	Biometric attendance divice issue resolved and ok working done check reader connection and divice seting with same employees card re add to divice	10-07-2025 10:41:07	Siddhesh Chavan	4th floor fire panel battery issue need to change battery						
Date Time	Technician Name	Remark																		
16-07-2025 10:15:16	Ravi Rajbhar	Biometric attendance divice issue resolved and ok working done check reader connection and divice seting with same employees card re add to divice																		
10-07-2025 10:41:07	Siddhesh Chavan	4th floor fire panel battery issue need to change battery																		