

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE14953																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	7400084949																			
Technician Name :	Siddhesh Chavan		Technician Mobile :	8080922985																
Ticket Type :	Complain	Date & Time :	09-06-2025 03:33:49																	
Vendor Details :																				
Company Name/Client Name :	JB Boda Dadar Site	Customer's Mobile :	7400084949	Name :	Jb Boda															
Address :																				
Mumbai , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Fire																			
Complain :	showing some error in panel need to check																			
Technician Comment :	Somke detector = 44 Gas leak = 1 Hooter = 2 Mcp = 1 Need to change system																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	Somke detector = 44 Gas leak = 1 Hooter = 2 Mcp = 1 Need to change system																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>09-06-2025 06:29:51</td><td>Siddhesh Chavan</td><td>Completed</td><td>Somke detector = 44 Gas leak = 1 Hooter = 2 Mcp = 1 Need to change system</td><td></td></tr><tr><td>09-06-2025 03:33:58</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	09-06-2025 06:29:51	Siddhesh Chavan	Completed	Somke detector = 44 Gas leak = 1 Hooter = 2 Mcp = 1 Need to change system		09-06-2025 03:33:58	Siddhesh Chavan	New		-
Date Time	Technician Name	Status	Remark	Sign																
09-06-2025 06:29:51	Siddhesh Chavan	Completed	Somke detector = 44 Gas leak = 1 Hooter = 2 Mcp = 1 Need to change system																	
09-06-2025 03:33:58	Siddhesh Chavan	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>24-05-2025 10:30:38</td><td>Atique Salmani</td><td>X990 c device att capacity full so it's not reading card or finger need download data and then clear data then issue res</td></tr><tr><td>16-05-2025 10:30:18</td><td>Atique Salmani</td><td>1 nos smoke detector collect with base for cheking only .</td></tr></tbody></table>					Date Time	Technician Name	Remark	24-05-2025 10:30:38	Atique Salmani	X990 c device att capacity full so it's not reading card or finger need download data and then clear data then issue res	16-05-2025 10:30:18	Atique Salmani	1 nos smoke detector collect with base for cheking only .						
Date Time	Technician Name	Remark																		
24-05-2025 10:30:38	Atique Salmani	X990 c device att capacity full so it's not reading card or finger need download data and then clear data then issue res																		
16-05-2025 10:30:18	Atique Salmani	1 nos smoke detector collect with base for cheking only .																		