




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE15228																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	7400084949																			
Technician Name :	Siddhesh Chavan		Technician Mobile :	8080922985																
Ticket Type :	Complain	Date & Time :	10-07-2025 10:41:07																	
Vendor Details :																				
Company Name/Client Name :	JB Boda Dadar Site	Customer's Mobile :	7400084949	Name :	Jb Boda															
Address :																				
Mumbai , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Fire																			
Complain :	4th floor panel showing battery failed error																			
Technician Comment :	4th floor fire panel battery issue need to change battery																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	4th floor fire panel battery issue need to change battery																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>10-07-2025 04:41:39</td><td>Siddhesh Chavan</td><td>Completed</td><td>4th floor fire panel battery issue need to change battery</td><td></td></tr><tr><td>10-07-2025 10:41:17</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	10-07-2025 04:41:39	Siddhesh Chavan	Completed	4th floor fire panel battery issue need to change battery		10-07-2025 10:41:17	Siddhesh Chavan	New		-
Date Time	Technician Name	Status	Remark	Sign																
10-07-2025 04:41:39	Siddhesh Chavan	Completed	4th floor fire panel battery issue need to change battery																	
10-07-2025 10:41:17	Siddhesh Chavan	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>16-07-2025 10:15:16</td><td>Ravi Rajbhar</td><td>Biometric attendance device issue resolved and ok working done check reader connection and device seting with same employees card re add to device</td></tr><tr><td>09-06-2025 03:33:49</td><td>Siddhesh Chavan</td><td>Somke detector = 44 Gas leak = 1 Hooter = 2 Mcp = 1 Need to change system</td></tr></tbody></table>					Date Time	Technician Name	Remark	16-07-2025 10:15:16	Ravi Rajbhar	Biometric attendance device issue resolved and ok working done check reader connection and device seting with same employees card re add to device	09-06-2025 03:33:49	Siddhesh Chavan	Somke detector = 44 Gas leak = 1 Hooter = 2 Mcp = 1 Need to change system						
Date Time	Technician Name	Remark																		
16-07-2025 10:15:16	Ravi Rajbhar	Biometric attendance device issue resolved and ok working done check reader connection and device seting with same employees card re add to device																		
09-06-2025 03:33:49	Siddhesh Chavan	Somke detector = 44 Gas leak = 1 Hooter = 2 Mcp = 1 Need to change system																		