




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE6892																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9819662812																			
Technician Name :	Yogesh Desai		Technician Mobile :	8080922963																
Ticket Type :	Complain	Date & Time :	19-11-2022 12:18:39																	
Vendor Details :																				
Company Name/Client Name :	Bellavista Building	Customer's Mobile :	9819662812	Name :	Jivan Patil															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	31-08-2021 12:00:00		Type :	Non-Comprehensive																
Product Name :	Ppm																			
Complain :	1402, 1403 intercom issue + Service need to do																			
Technician Comment :	ppm of cctv and intercom work completed all cameras are working properly with proper recording on all 3 DVRs there is no issue or complaint of cameras. intercom if 1402 issue solved 1403 intercom cable faulty from flat to duct need to be changed. ppm work completed .																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	ppm of cctv and intercom work completed all cameras are working properly with proper recording on all 3 DVRs there is no issue or complaint of cameras. intercom if 1402 issue solved 1403 intercom cable faulty from flat to duct need to be changed. ppm work completed .																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>19-11-2022 05:04:23</td><td>YogeshDesai</td><td>Completed</td><td>ppm of cctv and intercom work completed all cameras are working properly with proper recording on all 3 DVRs there is no issue or complaint of cameras. intercom if 1402 issue solved 1403 intercom cable faulty from flat to duct need to be changed. ppm work completed .</td><td></td></tr><tr><td>19-11-2022 12:20:10</td><td>YogeshDesai</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	19-11-2022 05:04:23	YogeshDesai	Completed	ppm of cctv and intercom work completed all cameras are working properly with proper recording on all 3 DVRs there is no issue or complaint of cameras. intercom if 1402 issue solved 1403 intercom cable faulty from flat to duct need to be changed. ppm work completed .		19-11-2022 12:20:10	YogeshDesai	New		-
Date Time	Technician Name	Status	Remark	Sign																
19-11-2022 05:04:23	YogeshDesai	Completed	ppm of cctv and intercom work completed all cameras are working properly with proper recording on all 3 DVRs there is no issue or complaint of cameras. intercom if 1402 issue solved 1403 intercom cable faulty from flat to duct need to be changed. ppm work completed .																	
19-11-2022 12:20:10	YogeshDesai	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>08-11-2022 05:06:57</td><td>Atique Salmani</td><td></td></tr><tr><td>07-11-2022 10:52:32</td><td>Atique Salmani</td><td>cat6 cable lay cancel wiring 25 meter flate to 12 floor duct done line working ok.</td></tr></tbody></table>					Date Time	Technician Name	Remark	08-11-2022 05:06:57	Atique Salmani		07-11-2022 10:52:32	Atique Salmani	cat6 cable lay cancel wiring 25 meter flate to 12 floor duct done line working ok.						
Date Time	Technician Name	Remark																		
08-11-2022 05:06:57	Atique Salmani																			
07-11-2022 10:52:32	Atique Salmani	cat6 cable lay cancel wiring 25 meter flate to 12 floor duct done line working ok.																		