

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE838																									
Priority :	High																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9833857590																								
Technician Name :	Atique Salmani		Technician Mobile :	8080922984																					
Ticket Type :	Complain	Date & Time :	25-12-2019 11:56:26																						
Vendor Details :																									
Company Name/Client Name :	Kiran Tower CHS	Customer's Mobile :	9833857590	Name :	Kalpesh Sir																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	30-06-2020 12:00:00		Type :	Non-Comprehensive																					
Product Name :	Fire																								
Complain :	fire alaram issue																								
Technician Comment :	need to do cabling of fire alarm system.																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	need to do cabling of fire alarm system.																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>27-12-2019 09:52:04</td><td>Atique Salmani</td><td>Completed</td><td>need to do cabling of fire alarm system.</td><td></td></tr><tr><td>25-12-2019 11:56:36</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr><tr><td>25-12-2019 11:56:27</td><td>Atique Salmani</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	27-12-2019 09:52:04	Atique Salmani	Completed	need to do cabling of fire alarm system.		25-12-2019 11:56:36	Atique Salmani	New		-	25-12-2019 11:56:27	Atique Salmani	New		-
Date Time	Technician Name	Status	Remark	Sign																					
27-12-2019 09:52:04	Atique Salmani	Completed	need to do cabling of fire alarm system.																						
25-12-2019 11:56:36	Atique Salmani	New		-																					
25-12-2019 11:56:27	Atique Salmani	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>02-08-2023 05:11:58</td><td>Kalpesh SubhashGurav</td><td>B Wing Lift no.2 intercom issue solved Intercom line running in Duct flat to Duct cable not found</td></tr><tr><td>26-07-2023 10:03:17</td><td>Kalpesh SubhashGurav</td><td>B Wing Lift No. 1 Intercom Problem Solved. A And B Wing Both Lift Intercom Checking Done. A/ 1203 OK B/ 1205 OK</td></tr></tbody></table>					Date Time	Technician Name	Remark	02-08-2023 05:11:58	Kalpesh SubhashGurav	B Wing Lift no.2 intercom issue solved Intercom line running in Duct flat to Duct cable not found	26-07-2023 10:03:17	Kalpesh SubhashGurav	B Wing Lift No. 1 Intercom Problem Solved. A And B Wing Both Lift Intercom Checking Done. A/ 1203 OK B/ 1205 OK											
Date Time	Technician Name	Remark																							
02-08-2023 05:11:58	Kalpesh SubhashGurav	B Wing Lift no.2 intercom issue solved Intercom line running in Duct flat to Duct cable not found																							
26-07-2023 10:03:17	Kalpesh SubhashGurav	B Wing Lift No. 1 Intercom Problem Solved. A And B Wing Both Lift Intercom Checking Done. A/ 1203 OK B/ 1205 OK																							