

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE1382																									
Priority :	High																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9623440945																								
Technician Name :	Yasin Shaikh		Technician Mobile :	8689802313																					
Ticket Type :	Complain	Date & Time :	16-03-2020 10:36:30																						
Vendor Details :																									
Company Name/Client Name :	Concentrix Services India Pvt. Ltd-Espace	Customer's Mobile :	9623440945	Name :	Kiran Pathebahadur																				
Address :																									
pune , , , 411014 , Maharashtra																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Access																								
Complain :	Access controller no : 2 not working																								
Technician Comment :	access controller no,02 working by power supply change all controller ok																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	access controller no,02 working by power supply change all controller ok																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>16-03-2020 12:01:07</td><td>YasinShaikh</td><td>Completed</td><td>access controller no,02 working by power supply change all controller ok</td><td></td></tr><tr><td>16-03-2020 10:38:38</td><td>YasinShaikh</td><td>New</td><td></td><td>-</td></tr><tr><td>16-03-2020 10:36:31</td><td>YasinShaikh</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	16-03-2020 12:01:07	YasinShaikh	Completed	access controller no,02 working by power supply change all controller ok		16-03-2020 10:38:38	YasinShaikh	New		-	16-03-2020 10:36:31	YasinShaikh	New		-
Date Time	Technician Name	Status	Remark	Sign																					
16-03-2020 12:01:07	YasinShaikh	Completed	access controller no,02 working by power supply change all controller ok																						
16-03-2020 10:38:38	YasinShaikh	New		-																					
16-03-2020 10:36:31	YasinShaikh	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>20-06-2021 04:21:05</td><td>MayurYadav</td><td>ppm of rodent system done all working ok</td></tr><tr><td>23-11-2020 12:59:50</td><td></td><td></td></tr></tbody></table>					Date Time	Technician Name	Remark	20-06-2021 04:21:05	MayurYadav	ppm of rodent system done all working ok	23-11-2020 12:59:50													
Date Time	Technician Name	Remark																							
20-06-2021 04:21:05	MayurYadav	ppm of rodent system done all working ok																							
23-11-2020 12:59:50																									