




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE1584																																			
Priority :	Low																																		
Created By :	Admin - Apurva Vajaria																																		
Complaint Mob. No. :	9967772241																																		
Technician Name :	Anil Yadav		Technician Mobile :	8080922983																															
Ticket Type :	Complain	Date & Time :	21-07-2020 12:40:22																																
Vendor Details :																																			
Company Name/Client Name :	Sai Akashdeep Chs Ltd	Customer's Mobile :	9967772241	Name :	Lobo																														
Address :																																			
Mumbai , , , 400064 , Maharashtra																																			
AMC Details :																																			
Expiry Date :	30-09-2020 12:00:00		Type :	Non-Comprehensive																															
Product Name :	Intercom																																		
Complain :	1601 intercom issue																																		
Technician Comment :	10th floor to 22th floor video not showing because 10th floor distributor up cable connection was dead . This complaint resolved. All floors video showing proper. 1601 in need new adopter.																																		
Complain Operator :	Desktop - Apurva Vajaria																																		
Remark :	10th floor to 22th floor video not showing because 10th floor distributor up cable connection was dead . This complaint resolved. All floors video showing proper. 1601 in need new adopter.																																		
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>30-07-2020 01:25:18</td><td>AnilYadav</td><td>Completed</td><td>10th floor to 22th floor video not showing because 10th floor distributor up cable connection was dead . This complaint resolved. All floors video showing proper. 1601 in need new adopter.</td><td></td></tr><tr><td>30-07-2020 12:20:48</td><td>AnilYadav</td><td>New</td><td></td><td>-</td></tr><tr><td>28-07-2020 12:02:10</td><td>AnilYadav</td><td>New</td><td></td><td>-</td></tr><tr><td>21-07-2020 06:06:57</td><td>AnilYadav</td><td>Client Side</td><td></td><td>-</td></tr><tr><td>21-07-2020 12:40:22</td><td>AnilYadav</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	30-07-2020 01:25:18	AnilYadav	Completed	10th floor to 22th floor video not showing because 10th floor distributor up cable connection was dead . This complaint resolved. All floors video showing proper. 1601 in need new adopter.		30-07-2020 12:20:48	AnilYadav	New		-	28-07-2020 12:02:10	AnilYadav	New		-	21-07-2020 06:06:57	AnilYadav	Client Side		-	21-07-2020 12:40:22	AnilYadav	New		-
Date Time	Technician Name	Status	Remark	Sign																															
30-07-2020 01:25:18	AnilYadav	Completed	10th floor to 22th floor video not showing because 10th floor distributor up cable connection was dead . This complaint resolved. All floors video showing proper. 1601 in need new adopter.																																
30-07-2020 12:20:48	AnilYadav	New		-																															
28-07-2020 12:02:10	AnilYadav	New		-																															
21-07-2020 06:06:57	AnilYadav	Client Side		-																															
21-07-2020 12:40:22	AnilYadav	New		-																															
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>07-08-2020 02:26:51</td><td>Siddhesh Chavan</td><td>2 flats vdp issue resolved 4 cctv video OK new powers supply installed now working OK</td></tr><tr><td>31-07-2020 06:17:44</td><td>Neeraj Chauhan</td><td></td></tr></tbody></table>					Date Time	Technician Name	Remark	07-08-2020 02:26:51	Siddhesh Chavan	2 flats vdp issue resolved 4 cctv video OK new powers supply installed now working OK	31-07-2020 06:17:44	Neeraj Chauhan																						
Date Time	Technician Name	Remark																																	
07-08-2020 02:26:51	Siddhesh Chavan	2 flats vdp issue resolved 4 cctv video OK new powers supply installed now working OK																																	
31-07-2020 06:17:44	Neeraj Chauhan																																		