

Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE2220																				
Priority :	High																			
Created By :	Customer - Madhu Sir- Mt																			
Complaint Mob. No. :	9742015015																			
Technician Name :		Technician Mobile :																		
Ticket Type :	Complain	Date & Time :	14-11-2020 08:37:53																	
Vendor Details :																				
Company Name/Client Name :	Concentrix Services India Private Limited - MT	Customer's Mobile :	9742015015	Name :	Madhu Sir-Mt															
Address :																				
Bangalore , , , 560037 , Karnataka																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00	Type :																		
Product Name :	Alarm System																			
Complain :	• 2nd Flr Delta trg room Access door properly not working • 2nd Flor Vm Ware #04 Access door is not close properly • 3rd Flr Godavari Trg room Buzzer is not working • 2nd Near FAO process fire exit door buzzer is not working • 2nd Flr PBA door near Sec																			
Technician Comment :																				
Complain Operator :	Desktop - Madhu Sir- Mt																			
Remark :	All access door problem solved. Now all doors working properly Buzzer working properly																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>19-11-2020 01:48:32</td><td></td><td>Completed</td><td></td><td>-</td></tr><tr><td>14-11-2020 08:37:54</td><td></td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	19-11-2020 01:48:32		Completed		-	14-11-2020 08:37:54		New		-
Date Time	Technician Name	Status	Remark	Sign																
19-11-2020 01:48:32		Completed		-																
14-11-2020 08:37:54		New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>10-11-2020 02:50:42</td><td></td><td>We checked the came BNC connector problem now that camera is working</td></tr><tr><td>31-10-2020 10:29:56</td><td></td><td>1 bnc connector replaced. Camera working ok</td></tr></tbody></table>					Date Time	Technician Name	Remark	10-11-2020 02:50:42		We checked the came BNC connector problem now that camera is working	31-10-2020 10:29:56		1 bnc connector replaced. Camera working ok						
Date Time	Technician Name	Remark																		
10-11-2020 02:50:42		We checked the came BNC connector problem now that camera is working																		
31-10-2020 10:29:56		1 bnc connector replaced. Camera working ok																		