




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE481																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9742015015																								
Technician Name :	Anil Yadav		Technician Mobile :	8080922983																					
Ticket Type :	New Installation	Date & Time :	03-10-2019 02:20:30																						
Vendor Details :																									
Company Name/Client Name :	Concentrix Services India Private Limited - MT	Customer's Mobile :	9742015015	Name :	Madhu Sir-Mt																				
Address :																									
Bangalore , , , 560037 , Karnataka																									
AMC Details :																									
Expiry Date :	01-01-1970 05:30:00		Type :																						
Product Name :	Access																								
Complain :	installation of PBA																								
Technician Comment :	1. 8 core cabling completed 84 MTR. 2. one single door PBA installed with two mc and one hooter. 3. one IP camera installed both systems working condition now.																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	1. 8 core cabling completed 84 MTR. 2. one single door PBA installed with two mc and one hooter. 3. one IP camera installed both systems working condition now.																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>03-10-2019 02:44:38</td><td>AnilYadav</td><td>Completed</td><td>1. 8 core cabling completed 84 MTR. 2. one single door PBA installed with two mc and one hooter. 3. one IP camera installed both systems working condition now.</td><td></td></tr><tr><td>03-10-2019 02:20:37</td><td>AnilYadav</td><td>New</td><td></td><td>-</td></tr><tr><td>03-10-2019 02:20:31</td><td>AnilYadav</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	03-10-2019 02:44:38	AnilYadav	Completed	1. 8 core cabling completed 84 MTR. 2. one single door PBA installed with two mc and one hooter. 3. one IP camera installed both systems working condition now.		03-10-2019 02:20:37	AnilYadav	New		-	03-10-2019 02:20:31	AnilYadav	New		-
Date Time	Technician Name	Status	Remark	Sign																					
03-10-2019 02:44:38	AnilYadav	Completed	1. 8 core cabling completed 84 MTR. 2. one single door PBA installed with two mc and one hooter. 3. one IP camera installed both systems working condition now.																						
03-10-2019 02:20:37	AnilYadav	New		-																					
03-10-2019 02:20:31	AnilYadav	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>14-11-2020 08:37:53</td><td></td><td>All access door problem solved. Now all doors working properly Buzzer working properly</td></tr><tr><td>10-11-2020 02:50:42</td><td></td><td>We checked the came BNC connector problem now that camera is working</td></tr></tbody></table>					Date Time	Technician Name	Remark	14-11-2020 08:37:53		All access door problem solved. Now all doors working properly Buzzer working properly	10-11-2020 02:50:42		We checked the came BNC connector problem now that camera is working											
Date Time	Technician Name	Remark																							
14-11-2020 08:37:53		All access door problem solved. Now all doors working properly Buzzer working properly																							
10-11-2020 02:50:42		We checked the came BNC connector problem now that camera is working																							