




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE6017																									
Priority :	Low																								
Created By :	Admin - Apurva Vajaria																								
Complaint Mob. No. :	9819810798																								
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																					
Ticket Type :	Complain	Date & Time :	23-07-2022 10:25:28																						
Vendor Details :																									
Company Name/Client Name :	Louis Palace Co Op Hsg Soc. Ltd	Customer's Mobile :	9819810798	Name :	Manoj Sir																				
Address :																									
Mumbai , , , , Maharashtra																									
AMC Details :																									
Expiry Date :	30-06-2021 12:00:00		Type :	Non-Comprehensive																					
Product Name :	Intercom																								
Complain :	A wing security cabin intercom issue																								
Technician Comment :	a wing security cabin intercom issue resolved and ok working done but cat 6 cable check 3 pair cable breck - green wight, blue wight, orange wight cable breck																								
Complain Operator :	Desktop - Apurva Vajaria																								
Remark :	a wing security cabin intercom issue resolved and ok working done but cat 6 cable check 3 pair cable breck - green wight, blue wight, orange wight cable breck																								
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>23-07-2022 03:35:07</td><td>Ravi Rajbhar</td><td>Completed</td><td>a wing security cabin intercom issue resolved and ok working done but cat 6 cable check 3 pair cable breck - green wight, blue wight, orange wight cable breck</td><td></td></tr><tr><td>23-07-2022 10:25:41</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr><tr><td>23-07-2022 10:25:28</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	23-07-2022 03:35:07	Ravi Rajbhar	Completed	a wing security cabin intercom issue resolved and ok working done but cat 6 cable check 3 pair cable breck - green wight, blue wight, orange wight cable breck		23-07-2022 10:25:41	Ravi Rajbhar	New		-	23-07-2022 10:25:28	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																					
23-07-2022 03:35:07	Ravi Rajbhar	Completed	a wing security cabin intercom issue resolved and ok working done but cat 6 cable check 3 pair cable breck - green wight, blue wight, orange wight cable breck																						
23-07-2022 10:25:41	Ravi Rajbhar	New		-																					
23-07-2022 10:25:28	Ravi Rajbhar	New		-																					
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>26-07-2022 10:49:53</td><td>SandeepGupta</td><td>cable faulty new cabling 120 meter work complete</td></tr><tr><td>05-07-2022 10:06:25</td><td>Atique Salmani</td><td>security cabin intrcom cable issue so use another pair working ok also a604 same isse issue resolved and v603 flate to duct new cabling due to renewal so find out extaiton nmbr and connected working ok.all completed .</td></tr></tbody></table>					Date Time	Technician Name	Remark	26-07-2022 10:49:53	SandeepGupta	cable faulty new cabling 120 meter work complete	05-07-2022 10:06:25	Atique Salmani	security cabin intrcom cable issue so use another pair working ok also a604 same isse issue resolved and v603 flate to duct new cabling due to renewal so find out extaiton nmbr and connected working ok.all completed .											
Date Time	Technician Name	Remark																							
26-07-2022 10:49:53	SandeepGupta	cable faulty new cabling 120 meter work complete																							
05-07-2022 10:06:25	Atique Salmani	security cabin intrcom cable issue so use another pair working ok also a604 same isse issue resolved and v603 flate to duct new cabling due to renewal so find out extaiton nmbr and connected working ok.all completed .																							