




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE10356																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9223207875																			
Technician Name :	Ravi Rajbhar		Technician Mobile :	8080922965																
Ticket Type :	Complain	Date & Time :	23-12-2023 10:55:31																	
Vendor Details :																				
Company Name/Client Name :	Shoppers Stop Ltd - HO	Customer's Mobile :	9223207875	Name :	Nandu Sir															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Fire																			
Complain :	During PPM found fire fault need to clear																			
Technician Comment :	both fire panel all faulty issue resolved and both panel battery issue need change battery 33 no. detector double add then one detector no. change 96 2no detector spear send to nandu sir																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	both fire panel all faulty issue resolved and both panel battery issue need change battery 33 no. detector double add then one detector no. change 96 2no detector spear send to nandu sir																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>23-12-2023 03:46:16</td><td>Ravi Rajbhar</td><td>Completed</td><td>both fire panel all faulty issue resolved and both panel battery issue need change battery 33 no. detector double add then one detector no. change 96 2no detector spear send to nandu sir</td><td></td></tr><tr><td>23-12-2023 10:55:40</td><td>Ravi Rajbhar</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	23-12-2023 03:46:16	Ravi Rajbhar	Completed	both fire panel all faulty issue resolved and both panel battery issue need change battery 33 no. detector double add then one detector no. change 96 2no detector spear send to nandu sir		23-12-2023 10:55:40	Ravi Rajbhar	New		-
Date Time	Technician Name	Status	Remark	Sign																
23-12-2023 03:46:16	Ravi Rajbhar	Completed	both fire panel all faulty issue resolved and both panel battery issue need change battery 33 no. detector double add then one detector no. change 96 2no detector spear send to nandu sir																	
23-12-2023 10:55:40	Ravi Rajbhar	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>16-12-2023 11:47:15</td><td>PravinJagade</td><td>3Rd floor and 5th floor fire ppm done.</td></tr><tr><td>15-12-2023 12:36:49</td><td>MayurYadav</td><td></td></tr></tbody></table>					Date Time	Technician Name	Remark	16-12-2023 11:47:15	PravinJagade	3Rd floor and 5th floor fire ppm done.	15-12-2023 12:36:49	MayurYadav							
Date Time	Technician Name	Remark																		
16-12-2023 11:47:15	PravinJagade	3Rd floor and 5th floor fire ppm done.																		
15-12-2023 12:36:49	MayurYadav																			