## Vallabh Enterprises

 $\label{eq:Regd.office:401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067 \\ \text{Support:} \mid \textbf{W}: www.vallabhenterprises.com \\ \textbf{E}: vallabhsecure@yahoo.co.in \\ \end{cases}$ 

Service Status Det	ails: VE10512					
Priority :	Low					
Created By:	Admin - Apurva Vajaria					
Complaint Mob. No. :	9223207875					
Technician Name	Mayur Yadav		<b>Technician Mobile :</b> 8411951301			
Ticket Type :	Complain Date & Time:		10-01-2024 05:17:10			
Vendor Details :			•			
Company Name/Client Name :	Shoppers Stop Ltd - HO	Customer's Mobile :	9223207875		Name :	Nandu Sir
Address :			<u>'</u>			
Mumbai , , , , Mah	arashtra					
AMC Details :						
Expiry Date :	01-01-1970 05:30:00 Type:					
<b>Product Name:</b>	CCTV					
Complain:	CCTV Survey need to do - How many days recording is going on need to check					
Technician Comment :	Cctv survey done Require 3 floor camera in one nvr And 5 floor camera in one nvr 45 days recording require					
Complain Operator :	Desktop - Apurva Vajaria					
Remark:	Cctv survey done Require 3 floor camera in one nvr And 5 floor camera in one nvr 45 days recording require					
Status History :	Date Time	Technician Name	Status	Remark		Sign
	11-01-2024 01:06:11	MayurYadav	Completed	Cctv survey done Require 3 floor camera in one nvr And 5 floor camera in one nvr 45 days recording require		July
	11-01-2024 10:20:45	MayurYadav	New			-
Previous Complain History	Date Time	Technician Name	Remark			
;	23-12-2023 10:55:31	Ravi Rajbhar	both fire panal all faulty issue resolved and both panal battery issue need change battery 33 no. detector double add then one detector no. change 96 2no detector speair send to nandu sir			
	16-12-2023 11:47:15	PravinJagade	3Rd floor and 5th floor fire ppm done.			