




Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067
Support : | W : www.vallabhenterprises.com
E : vallabhsecure@yahoo.co.in

Service Status Details : VE10750																				
Priority :	Low																			
Created By :	Admin - Apurva Vajaria																			
Complaint Mob. No. :	9223207875																			
Technician Name :	Siddhesh Chavan		Technician Mobile :	8080922985																
Ticket Type :	New Installation	Date & Time :	03-02-2024 02:07:13																	
Vendor Details :																				
Company Name/Client Name :	Shoppers Stop Ltd - HO	Customer's Mobile :	9223207875	Name :	Nandu Sir															
Address :																				
Mumbai , , , , Maharashtra																				
AMC Details :																				
Expiry Date :	01-01-1970 05:30:00		Type :																	
Product Name :	Fire																			
Complain :	both fire panel battery need to change																			
Technician Comment :	3rd and 5th floor fire panel battery change and all smoke director clining done and 5th floor washroom out side smoke director issue need to chnge																			
Complain Operator :	Desktop - Apurva Vajaria																			
Remark :	3rd and 5th floor fire panel battery change and all smoke director clining done and 5th floor washroom out side smoke director issue need to chnge																			
Status History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Status</th><th>Remark</th><th>Sign</th></tr></thead><tbody><tr><td>03-02-2024 06:21:08</td><td>Siddhesh Chavan</td><td>Completed</td><td>3rd and 5th floor fire panel battery change and all smoke director clining done and 5th floor washroom out side smoke director issue need to chnge</td><td></td></tr><tr><td>03-02-2024 02:07:19</td><td>Siddhesh Chavan</td><td>New</td><td></td><td>-</td></tr></tbody></table>					Date Time	Technician Name	Status	Remark	Sign	03-02-2024 06:21:08	Siddhesh Chavan	Completed	3rd and 5th floor fire panel battery change and all smoke director clining done and 5th floor washroom out side smoke director issue need to chnge		03-02-2024 02:07:19	Siddhesh Chavan	New		-
Date Time	Technician Name	Status	Remark	Sign																
03-02-2024 06:21:08	Siddhesh Chavan	Completed	3rd and 5th floor fire panel battery change and all smoke director clining done and 5th floor washroom out side smoke director issue need to chnge																	
03-02-2024 02:07:19	Siddhesh Chavan	New		-																
Previous Complain History :	<table><thead><tr><th>Date Time</th><th>Technician Name</th><th>Remark</th></tr></thead><tbody><tr><td>28-02-2024 12:30:50</td><td>PravinJagade</td><td>3 floor and 5 floor camera sequence Done. 2 camera offline issue resolve working done 1 camera no video issue not resolved. Work complete</td></tr><tr><td>17-02-2024 02:49:37</td><td>MayurYadav</td><td>Fault in main power board in 3rd and 5th floor panel</td></tr></tbody></table>					Date Time	Technician Name	Remark	28-02-2024 12:30:50	PravinJagade	3 floor and 5 floor camera sequence Done. 2 camera offline issue resolve working done 1 camera no video issue not resolved. Work complete	17-02-2024 02:49:37	MayurYadav	Fault in main power board in 3rd and 5th floor panel						
Date Time	Technician Name	Remark																		
28-02-2024 12:30:50	PravinJagade	3 floor and 5 floor camera sequence Done. 2 camera offline issue resolve working done 1 camera no video issue not resolved. Work complete																		
17-02-2024 02:49:37	MayurYadav	Fault in main power board in 3rd and 5th floor panel																		