

# Vallabh Enterprises

Regd. Office : 401,shanti kutir,shivaji road,near thakur international school,kandivali(west) mumbai - 400067  
 Support : | W : www.vallabhenterprises.com  
 E : vallabhsecure@yahoo.co.in

<b>Service Status Details : VE10975</b>																				
<b>Priority :</b>	Low																			
<b>Created By :</b>	Admin - Apurva Vajaria																			
<b>Complaint Mob. No. :</b>	9223207875																			
<b>Technician Name :</b>	Pravin Jagade	<b>Technician Mobile :</b>	7262044153																	
<b>Ticket Type :</b>	Complain	<b>Date &amp; Time :</b>	28-02-2024 12:30:50																	
<b>Vendor Details :</b>																				
<b>Company Name/Client Name :</b>	Shoppers Stop Ltd - HO	<b>Customer's Mobile :</b>	9223207875	<b>Name :</b>	Nandu Sir															
<b>Address :</b>																				
Mumbai , , , Maharashtra																				
<b>AMC Details :</b>																				
<b>Expiry Date :</b>	01-01-1970 05:30:00	<b>Type :</b>																		
<b>Product Name :</b>	CCTV																			
<b>Complain :</b>	2nd floor/3rd floor/4th floor cameras need to do floorwise																			
<b>Technician Comment :</b>	3 floor and 5 floor camera sequence Done. 2 camera offline issue resolve working done 1 camera no video issue not resolved. Work complete																			
<b>Complain Operator :</b>	Desktop - Apurva Vajaria																			
<b>Remark :</b>	3 floor and 5 floor camera sequence Done. 2 camera offline issue resolve working done 1 camera no video issue not resolved. Work complete																			
<b>Status History :</b>	<table border="1"> <thead> <tr> <th>Date Time</th> <th>Technician Name</th> <th>Status</th> <th>Remark</th> <th>Sign</th> </tr> </thead> <tbody> <tr> <td>02-03-2024 07:33:43</td> <td>PravinJagade</td> <td>Completed</td> <td>3 floor and 5 floor camera sequence Done. 2 camera offline issue resolve working done 1 camera no video issue not resolved. Work complete</td> <td></td> </tr> <tr> <td>02-03-2024 10:43:30</td> <td>PravinJagade</td> <td>New</td> <td></td> <td>-</td> </tr> </tbody> </table>					Date Time	Technician Name	Status	Remark	Sign	02-03-2024 07:33:43	PravinJagade	Completed	3 floor and 5 floor camera sequence Done. 2 camera offline issue resolve working done 1 camera no video issue not resolved. Work complete		02-03-2024 10:43:30	PravinJagade	New		-
Date Time	Technician Name	Status	Remark	Sign																
02-03-2024 07:33:43	PravinJagade	Completed	3 floor and 5 floor camera sequence Done. 2 camera offline issue resolve working done 1 camera no video issue not resolved. Work complete																	
02-03-2024 10:43:30	PravinJagade	New		-																
<b>Previous Complain History :</b>	<table border="1"> <thead> <tr> <th>Date Time</th> <th>Technician Name</th> <th>Remark</th> </tr> </thead> <tbody> <tr> <td>17-02-2024 02:49:37</td> <td>MayurYadav</td> <td>Fault in main power board in 3rd and 5th floor panel</td> </tr> <tr> <td>03-02-2024 02:07:13</td> <td>Siddhesh Chavan</td> <td>3rd and 5th floor fire panel battery change and all smoke director clining done and 5th floor washroom out side smoke director issue need to chnge</td> </tr> </tbody> </table>					Date Time	Technician Name	Remark	17-02-2024 02:49:37	MayurYadav	Fault in main power board in 3rd and 5th floor panel	03-02-2024 02:07:13	Siddhesh Chavan	3rd and 5th floor fire panel battery change and all smoke director clining done and 5th floor washroom out side smoke director issue need to chnge						
Date Time	Technician Name	Remark																		
17-02-2024 02:49:37	MayurYadav	Fault in main power board in 3rd and 5th floor panel																		
03-02-2024 02:07:13	Siddhesh Chavan	3rd and 5th floor fire panel battery change and all smoke director clining done and 5th floor washroom out side smoke director issue need to chnge																		